

LAYOUT 4/26/02 11:00 INSP 4 _____
 INSP 2 4/29/02 PM INSP 5 _____
 INSP 3 7/9/02 12:00 INSP 6 _____

pumps test

ISSUE DATE: 4/17/2002
 APPROVAL DATE: 7/9/02

PERMIT INDEXED

P 516935
 A 56539-A

ON-SITE SEWAGE DISPOSAL SYSTEM HOWARD COUNTY HEALTH DEPARTMENT BUREAU OF ENVIRONMENTAL HEALTH

Fogles Septic Clean, Inc IS PERMITTED TO . INSTALL ALTER

ADDRESS: 580 Obrecht Road, Sykesville PHONE NUMBER: 410-795-5670
 SUBDIVISION: Kasemeyer Property LOT NUMBER: 7
 ADDRESS: 2650 Pfefferkorn Road PROPERTY OWNER: DAVID MC CARL Catonsville Builders, Inc.

SEPTIC TANK CAPACITY (GALLONS): 1250 OUTLET BAFFLE FILTER REQUIRED
 PUMP CHAMBER CAPACITY (GALLONS): N/A 1250 COMPARTMENTED TANK REQUIRED
 NUMBER OF BEDROOMS: 4
 SQUARE FEET PER BEDROOM: 210
 LINEAR FEET OF TRENCH REQUIRED: 280

TRENCHES:	Trench to be 3.0 feet wide. Inlet 4.0 feet below original grade. Bottom maximum depth 6.0 feet below original grade. Effective area begins at 4.0 feet below original grade. 2.0 feet of stone below distribution pipe.
LOCATION:	Place the distribution box 100 feet from the lot line parallel to Pfeffkorn Road and 20 feet from the existing paved access road. Run two 50 feet and two 90 foot trenches to the edge of the existing paved access.
NOTES:	<u>Check well to house distance.</u>

PLANS APPROVED: Brian Baker OK SRK 1/11/01 DATE: 1/10/2002

- NOTE: PERMIT VOID AFTER 2 YEARS
- NOTE: CONTRACTOR RESPONSIBLE FOR SCHEDULING A PRE-CONSTRUCTION INSPECTION FOR ALL INSTALLATIONS
- NOTE: WATERTIGHT SEPTIC TANKS REQUIRED
- NOTE: ALL PARTS OF SEPTIC SYSTEM SHALL BE 100 FEET FROM ANY WATER WELL
- NOTE: MANHOLE RISERS REQUIRED ON ALL SEPTIC TANKS AND PUMP CHAMBERS UNLESS SPECIFICALLY AUTHORIZED

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM PERMITTEE RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT ALL 410-313-2640 FOR INSPECTION OF SEPTIC SYSTEM

BUILDING PERMIT SIGNED AND RETURNED

*2/6/2003 B00140244 OPEN PORCH
 3/19/04 B00140806 - ENTRY FEATURE + LANDSCAPING*

7000017

