



Bureau of Environmental Health

8930 Stanford Boulevard, Columbia, MD 21045

Main: 410-313-2640 | Fax: 410-313-2648

TDD 410-313-2323 | Toll Free 1-866-313-6300

www.hchealth.org

Facebook: www.facebook.com/hocohealth

Maura J. Rossman, M.D., Health Officer

RECEIPT DATE: 3-17 **ONSITE SEWAGE DISPOSAL SYSTEM**

P 30561

PERMIT

INSTALLATION APPROVAL DATE: 6/29/17 *(km)*

A _____

SEWER HOUSE CONNECTION

PROPERTY ADDRESS: 5119 Honey Locust Court

SUBDIVISION: Walnut Creek LOT: 42 TAX ID: 05-595183

CONTRACTOR: Robert A. Tull, Inc. EMAIL: _____

CONTRACTOR ADDRESS: 7820 Airpark Rd. / Gaithersburg, MD 20879 PHONE: 301-948-2490

PROPERTY OWNER: BV Business Trust EMAIL: _____

OWNER ADDRESS: P.O. Box 982, Lisbon, MD 21064 PHONE: _____

NUMBER OF BEDROOMS: 5 CONNECTED TO PUBLIC WATER: YES NO

LOCATION:	INSTALL 4" SEWER LINE PER APPROVED SITE PLAN.
NOTES:	

ISSUED BY: Robert Freemon ISSUE DATE: 3-17 EXPIRATION DATE: 3-18

NOTE: HOWARD COUNTY BUREAU OF UTILITIES APPROVAL OF GRINDER PUMP INSTALLATION IS REQUIRED PRIOR TO SEPTIC PERMIT APPROVAL

NOTE: CONTRACTOR MUST SCHEDULE AN INSPECTION AND GAIN APPROVAL OF ALL COMPONENTS PRIOR TO COVERING

NOTE: AN ELECTRICAL PERMIT IS REQUIRED FOR INSTALLATION OF ANY ELECTRICAL COMPONENTS OF THE SYSTEM

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM. PERMITTEE RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT. CALL 410-313-1771 FOR INSPECTION OF SEPTIC SYSTEM.

Wolf, Kevin

From: Fisher, Mike
Sent: Monday, June 19, 2017 10:00 AM
To: Miscbilling
Cc: Hart, Amy; Rocco, Anthony; Martin, Sharhonda; Williams, Jeffrey; Bozzell, Duane; Bernard, Dana; Wolf, Kevin; Collins, Sarah; John Pavlik; Tuder, Matt
Subject: U&O Release 5119 Honey Locust Court

On the morning of June 2nd, Duane Bozzell observed the start-up of a Sewage Grinder Pump at the Walnut Creek Shared Septic System:

Walnut Creek, Contract #4530
Craftmark Homes, Lot #42
5119 Honey Locust Ct.
Ellicott City, MD 21042

The Sewage Grinder Pump test was successful; the Bureau of Utilities releases its hold on this property for U&O.

Thank You.

Michael D. Fisher Jr.
Operations Supervisor 1
DPW-Bureau of Utilities
Phone: (410)313-4975
Fax: (410)313-4989

