

STATE OF MARYLAND
DEPARTMENT OF HEALTH AND MENTAL HYGIENE
LABORATORIES ADMINISTRATION
201 W. Preston Street
PO BOX 2355, Baltimore, Maryland 21203
John M. Deboy, Dr. P.H., Director

Retest

010804

Category Code 4F

Lab. No. _____

BACTERIOLOGICAL DRINKING WATER REPORT
Field Record

Source Debbie Izzi 1st Floor Powder Room
 Location: 3226 Parliament Place
 Iced: Yes No a.m.
 Treated Yes No Time Collected 9:00 p.m.
 Collector # 3166KH Bottle No. HC3226-1
 Collector Name Kerrie Hamilton County Howard

TEST
 QUANTITATIVE P/A MTF
 pH 7.0 Res. Cl: Free 00 Total 00 Card No.
 County 13 Plant No. Sampling Station Date Collected 12 16 08

LABORATORY RECORD

Thiosulfate: Pres. Absent Undetermined

PRESUMPTIVE MTF • P/A TEST*				CONFIRMED MTF • P/A TEST				No. of +
ml of Sample	10 ml.	100 ml.	ml of Sample	10 ml.	100 ml.			
Gas. 24 hours			Coliforms †					
Gas. 48 hours			Fecal Coliforms ‡					

P/A TEST (CONFIRMED) ***

ml. of Sample	100 ml.
Total Coliforms	
E. Coli	

QUANTITATIVE TEST (CONFIRMED) ***

100 ml. of Sample	No. of Pos	MPN
Total Coliforms	<u>35</u>	<u>59</u>
E. Coli	<u>0</u>	<u>2</u>

** Presumptive Coliforms/100 ml. (Membrane Filter) =
 † Verified Total Coliforms/100 ml. (Membrane Filter) ÷
 ‡ Verified Fecal Coliforms/100 ml. (Membrane Filter) =

24 • 48 • 72 Hrs/Heterophic Plate Count §/ml. =

Temp. Control 5.0 °C Lmp
 ** using m Endo-Agar LES at 35° C incubation
 * using Lauryl Sulfate Trypticase Broth at 35° C incubation
 † using Brilliant Green Lactose Bile Broth at 35° C incubation
 ‡ using EC Broth at 44.5° C incubation
 § using Plate Count Agar at 35° C incubation
 *** using ONPG-MCG at 35° C incubation

Remarks _____ Date & Hour _____ Laboratory _____

08 DEC 16 PM 2:22 Rec.d _____ E. SHORE REG. S. MD REG.
08 DEC 16 PM 2:33 Exam Lmp CENTRAL W. MD REG.
08 DEC 17 PM 2:37 Rept. SA Bacteriologist B. Hill

(4)

STATE OF MARYLAND
DEPARTMENT OF HEALTH AND MENTAL HYGIENE
LABORATORIES ADMINISTRATION
201 W. Preston Street
PO BOX 2355, Baltimore, Maryland 21203
John M. Deboy, Dr. P.H., Director

Category Code 4F

Lab. No. 010803

BACTERIOLOGICAL DRINKING WATER REPORT
Field Record

Community
Non-Community
Non-Transient
Private
Check Sample
C.O.P.

Source: Debbie Izzi and Floor
Location: 3226 Parliament Place Bathroom
Iced: Yes No a.m.
Treated Yes No Time Collected 9:10 p.m.
Collector # 3166 KH Bottle No. HC3226-2
Collector Name Kerrrie Hamilton County Howard

TEST
QUANTITATIVE
P/A
MTF
pH 7.0 Res. Cl: Free 00 Total 00 Card No.

County 13 Plant No. Sampling Station Date Collected 12 16 08

LABORATORY RECORD

Thiosulfate: Pres. Absent Undetermined

PRESUMPTIVE MTF • P/A TEST*

CONFIRMED MTF • P/A TEST

ml of Sample	10 ml.	100 ml.	ml of Sample	10 ml.	100 ml.	No. of +
Gas, 24 hours			Coliforms †			
Gas, 48 hours			Fecal + Coliforms +			

P/A TEST (CONFIRMED) ***

ml. of Sample	100 ml.
Total Coliforms	
E. Coli	

QUANTITATIVE TEST (CONFIRMED) ***

100 ml. of Sample	No. of Pos	MPN
Total Coliforms	<u>28</u>	<u>41</u>
E. Coli	<u>0</u>	<u><1</u>

** Presumptive Coliforms/100 mi. (Membrane Filter) =
† Verified Total Coliforms/100 mi. (Membrane Filter) ÷
‡ Verified Fecal Coliforms/100 mi. (Membrane Filter) =

24 • 48 • 72 Hrs/Heterophic Plate Count §/ml. =

Temp. Control 5.0 °C Imp

- ** using m Endo-Agar LES at 35° C incubation
- * using Lauryl Sulfate Trypticase Broth at 35° C incubation
- † using Brilliant Green Lactose Bile Broth at 35° C incubation
- ‡ using EC Broth at 44.5° C incubation
- § using Plate Count Agar at 35° C incubation
- *** using ONPG-MCG at 35° C incubation

Remarks _____
Date & Hour
08 DEC 16 PM 2:22
08 DEC 16 PM 2:33
08 DEC 17 PM 2:37

Laboratory
E. SHORE REG. S. MD REG.
CENTRAL W. MD REG.
Bacteriologist B. Hill

STATE OF MARYLAND
DEPARTMENT OF HEALTH AND MENTAL HYGIENE
LABORATORIES ADMINISTRATION

4

201 W. Preston Street
PO BOX 2355, Baltimore, Maryland 21203
John M. Deboy, Dr. P.H., Director

Retest

010808

Category Code 4F

Lab. No.

BACTERIOLOGICAL DRINKING WATER REPORT
Field Record

- Community
- Non-Community
- Non-Transient
- Private
- Check Sample
- D.O.P.

Source: ~~3226~~ Cobble Izzie, 2nd Floor
 Location: 3226 Parliament Place Bathroom
 Load: Yes No a.m.
 Treated: Yes No Time Collected: 9:10 p.m.
 Collector #: 2166 KH Bottle No. HC3226-2
 Collector Name: Kerrie Hamilton County: Howard

TEST QUANTITATIVE
 P/A
 MTF
 pH: 7.0 Res. Cl: Proc: 00 Total: 00 Card No.:
 County: 13 Plant No.: Sampling Station: Date Collected: 12 16 08

LABORATORY RECORD

Thiosulfate: Pres. Absent Undetermined

PRESUMPTIVE MTF • P/A TEST*

CONFIRMED MTF • P/A TEST

No. of Sample	10 ml.		100 ml.		No. of +
	Coliforms	E. coli	Coliforms	E. coli	
in 24 hours					
in 48 hours					

P/A TEST (CONFIRMED) ***

ml. of Sample	100 ml.
Total Coliforms	
E. coli	

QUANTITATIVE TEST (CONFIRMED) ***

100 ml. of Sample	No. of Pos	MPN
Total Coliforms	28	41
E. coli	0	<1

** Presumptive Coliforms/100 ml. (Membrane Filter) =
 † Verified Total Coliforms/100 ml. (Membrane Filter) =
 ‡ Verified Fecal Coliforms/100 ml. (Membrane Filter) =

24 • 48 • 72 Hrs/Heterophilic Plate Count ϕ /ml. =

Temp. Control 5.0 °C imp

- ** using m Endo-Agar LES at 35° C incubation
- † using Lauryl Sulfate Trypticase Broth at 35° C incubation
- ‡ using Brilliant Green Lactose Bile Broth at 35° C incubation
- ‡ using EC Broth at 44.5° C incubation
- ‡ using Plate Count Agar at 35° C incubation
- *** using ONPG-MCG at 35° C incubation

Remarks

Date & Hour

Laboratory

08 DEC 16 PM 2:22

08 DEC 16 PM 2:33

08 DEC 17 PM 2:37

Rec'd
LMP
EPA
BPA
MWH

E. SHORE REG. S. MD REG.
 CENTRAL W. MD REG.
 W. MD REG. P. Hill

12/17/08 Sgt. VMJ
 informing Izzie
 of still breeding
 to disinfect.
 again. Also to
 call me after
 doing so in
 order to sched. it