

March 2, 2017

Nanette Bonsby
2286 Duvall Road
Woodbine, MD 21797

Mr. Mike Davis,

I would like a waiver to the regulation for the perk testing on my property at 2286 Duvall Road, Woodbine, MD 21797. The reasons for the waiver are that we have 8 acres of land and the pool would be within the 100 feet of the well.

Sincerely,

Nanette Bonsby
Nanette Bonsby

4/5/17
Approved
Michael J Davis



Bureau of Environmental Health

8930 Stanford Boulevard, Columbia, MD 21045

Main: 410-313-2640 | Fax: 410-313-2648

TDD 410-313-2323 | Toll Free 1-866-313-6300

www.hchealth.org

Facebook: www.facebook.com/hocohealth

Twitter: HowardCoHealthDep

Maura J. Rossman, M.D., Health Officer

April 5, 2017

Nanette Bonsby
2286 Duvall Road
Woodbine, MD 21797

RE: Waiver Approval
2286 Duvall Road
Woodbine, MD 21797

Dear Ms. Bonsby,

This letter is being issued in response to your waiver request received on March 2, 2017. This agency has **approved** the waiver to the required perc testing and Percolation Certification Plan. The approval is based on the fact that the proposed pool is within the one hundred foot (100) foot setback to the existing water well and therefore, the area is not useable for future on-site sewage disposal system repairs. As a condition of this waiver approval, the casing for the existing water well must be extended at least eight (8) inches above grade with a water tight two piece cap or equivalent and an electrical conduit extending at least eight (8) inches below grade. Any deviations from the proposed work indicated on the building permit site plan will be subject to further review by this Department. Future living space additions will likely require perc testing and a Percolation Certification Plan.

Any questions regarding this decision may be directed to the Well and Septic Program of the Howard County Health Department.

Respectfully,

A handwritten signature in black ink that reads 'Michael J. Davis'.

Michael J. Davis
Assistant Director
Bureau of Environmental Health