

CARROLL WATER SYSTEMS  
60 AILERON COURT, SUITE #3  
WESTMINSTER, MD 21157  
410-876-5100

**HOWARD COUNTY YIELD TEST REPORT**

Date Test Performed: 06-09-2016  
Address: 11202 Old Hopkins Road  
Owner Name: Esther Dastouri  
Well Depth: 500 Ft

Permit Number: HO-95-0220  
Subdivision:  
Election District:  
Static Water Level: 224 Ft

Time	Water Level	PSI Existing Pump	Pumping Rate Seconds to fill 1 gallon bucket	Calculated Flow-Gallons Per Minute
0915	224 ft	10psi	13 sec	4.62
0930	277	10	14	4.29
0945	323	15	48	1.25
1000	346	20	56	1.07
1015	346	20	56	1.07
1030	346	20	56	1.07
1045	346	20	56	1.07
1100	346	20	56	1.07
1115	346	20	56	1.07
1130	346	20	56	1.07
1145	346	20	56	1.07
1200	346	20	56	1.07
1215	346	20	56	1.07
1230	346	20	56	1.07
1245	346	20	56	1.07
1300	346	20	56	1.07
1315	346	20	56	1.07
1330	346	20	56	1.07
1345	346	20	56	1.07
1400	346	20	56	1.07
1415	346	20	56	1.07
1430	346	20	56	1.07
1445	346	20	56	1.07
1500	346	20	56	1.07
1515	346	20	56	1.07
1530	346	20	56	1.07
1545	346	20	56	1.07