



PERMIT CARD \_\_\_\_\_

SEPTIC TANK, LEVEL OK 1500

CLEANOUTS

ST	DW	
NO 7/16	NO 7/16	LC
OK 7/17	OK 7/17	SC

DISTRIBUTION BOX, LEVEL TOP 2 FT BELOW GRADE

TILE FIELD, DEPTH 4 FT. TRENCH WIDTH 2-5 FT.

GRAVEL DEPTH 3 TO 6 IN. TOTAL LENGTH 58 FT.

NUMBER OF TRENCHES 2 TOTAL BOTTOM AREA \_\_\_\_\_

SEEPAGE PITS, INSIDE DIAMETER 47 FT. DEPTH BELOW INLET 6 FT.

ABSORBENT AREA 282 SQ. FT.

REMARKS 7/16/77 ADD STONE TO DITCH CEMENT  
SEWER LINES INSTALL CLEANOUTS ADD ANOTHER  
25 FT LONG DITCH TO DW BUT DONOT ADD STONE  
& CALL BGR/IT - 7/16/77 DITCH #1 - 9 FT DEEP 2 FT WIDE  
6 FT STONE - 150 SQ FT - DW INLET 3 FT BELOW GRADE  
DITCH #2 - SEE BACK OF YELLOW WELL PERM 19

DATE SYSTEM APPROVED 7/17/77

INSPECTOR Raymond [Signature]