

FOUNTAIN VALLEY ANALYTICAL LABORATORY, INC.

1413 Old Taneytown Rd. Westminster, MD (410) 848-1014 (410) 876-4554 FAX (410) 848-0298

REPORT OF ANALYSIS

Laboratory ID #: 102084 Account #: 7108
Reference: Howard County Certification/Green Company: Leffler Construction
Location: 13535 Argo Drive Requested By: Greg Leffler
Dayton, MD 21036 Source: Well Water
Date/ Time Collected: 7/22/2015 1000 Site: Master Bedroom Bathroom Tap
Date/Time Rec'd: 7/22/2015 1315 Treatment: Sediment Filter/Neutralizer
Chlorine ppm: Free: ND Total: ND pH: 5.9
Collected By: C. Mooshian 7268CM Well #: HO-73-1151

PARAMETERS	RESULTS	UNITS	REFERENCE	METHOD	DATE/TIME/ANALYST
Bacteria, Coliform, Total, MPN	<1.0	MPN/ 100 ml	<1.0	SM18 9223	7/23/2015 / 1030 / CCH
Bacteria, E. coli, MPN	<1.0	MPN/ 100 ml	<1.0	SM18 9223	7/23/2015 / 1030 / CCH
Nitrate	9.63	mg/L	10	601	7/22/2015 / 1630 / CWM

NOTES

- 1 mg/L = milligrams per liter (also, parts per million)
- 2 MPN/ 100 ml = Most Probable Number [of viable bacteria] per 100 ml of sample.
- 3 Results less than or within the reference range are considered satisfactory and within potable water limits at the time of sampling.
- 4 ND:None Detected
- 5 pH & Chlorine level tested on site
- 6 Visual well check: Single piece cap

Reason for Test : Client's InformationDate Reported: 7/23/2015