

**STATE OF MARYLAND**  
**WATER RESOURCES ADMINISTRATION**  
**TAWES STATE OFFICE BLDG., ANNAPOLIS, MD. 21401**  
**WELL COMPLETION REPORT**

THIS REPORT MUST BE SUBMITTED IN 30 DAYS AFTER WELL COMPLET

FILL IN THIS FORM COMPLETELY

COUNTY NUMBER

SEQUENCE NO. (WRA USE ONLY) **3253**

DATE RECEIVED (WRA USE ONLY) **3/10/78**

DEPTH OF WELL **120** (TO NEAREST FOOT)

PERMIT NO. FROM "PERMIT TO DRILL WELL" **HC-73-2769**

DRILLERS IDENTIFICATION NO. **42**

OWNER **TECH-CON DEVEL INC** LAST NAME **TECH-CON** FIRST NAME **TECH-CON**

STREET OR RFD **3000 CENTURY RD** POST OFFICE **COLUMBIA, MD**

**WELL LOG**

STATE THE KIND OF FORMATION'S PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING

DESCRIPTION (USE ADDITIONAL SHEETS IF NECESSARY)	FEET	CHECK IF WATER BEARING
FROM	TO	
TOP SOIL	0	2
SAND	2	10
BROWN SILT	10	85
BLUE SLATE	85	120

**GROUTING RECORD**

WELL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX)  Y  N

TYPE OF GROUTING MATERIAL (CIRCLE BOX):  
 CEMENT  BENTONITE CLAY

NO. OF BAGS **7** NO. OF POUNDS **700**

GALLONS OF WATER **95**

DEPTH OF GROUT SEAL (TO NEAREST FOOT)  
 FROM **0** FT. TO **30** FT.

**CASING RECORD**

INSERT APPROPRIATE CODE BELOW

STEEL  CONCRETE   
 PLASTIC  OTHER

MAIN CASING TYPE **ST** NOMINAL DIAMETER **6** INCH TOTAL DEPTH **31** FEET

**OTHER CASING (IF USED)**

DIAMETER (INCH) FROM TO

**SCREEN RECORD**

INSERT APPROPRIATE CODE BELOW

STEEL  BRASS OR BRONZE  OPEN HOLE   
 PLASTIC  OTHER

**EACH SCREEN**

SCREEN NO.	DEPTH (NEAREST WHOLE FOOT) FROM	TO
1	8	11
2	23	24
3	38	39

SLOT SIZE 1, 2, 3

**PUMPING TEST**

HOURS PUMPED (TO NEAREST HOUR) **2**

PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON) **15**

METHOD USED TO MEASURE PUMPING RATE **BUCKET**

WATER LEVEL (DISTANCE FROM LAND SURFACE)  
 BEFORE PUMPING **35** FEET  
 WHEN PUMPING **130** FEET

TYPE OF PUMPED USED (CIRCLE APPROPRIATE BOX)  
 AIR  PISTON  TURBINE  
 CENTRIFUGAL  ROTARY  OTHER  
 JET  SUBMERSIBLE

**PUMP INSTALLED**

TYPE OF PUMP (WRITE APPROPRIATE LETTER IN BOX - SEE ABOVE: A, C, J, P, R, S, T, O)

DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX)  YES  NO

CAPACITY: GALLONS PER MINUTE (TO NEAREST GALLON) **31** TO **35**

PUMP HORSE POWER **37** TO **41**

PUMP COLUMN LENGTH (NEAREST FOOT) **43** TO **47**

**CASING HEIGHT** (CIRCLE APPROPRIATE BOX AND ENTER CASING HEIGHT)

ABOVE LAND SURFACE  BELOW

**LOCATION OF WELL ON LOT**

SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL).

**CIRCLE APPROPRIATE BOXES**

A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED

E ELECTRIC LOG OBTAINED

P TEST WELL CONVERTED TO PRODUCTION WELL

I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

DRILLERS NAME **L.F. EASTERN**

SIGNATURE **L.F. Eastern**

DIAMETER OF SCREEN **56** (NEAREST INCH) FROM **56** TO **60**

GRAVEL PACK

IF WELL DRILLED WAS A FLOWING WELL CIRCLE BOX  F

WRA USE ONLY (NOT TO BE FILLED IN BY DRILLER)

TELESCOPE CASING  LOG INDICATOR

WELL 30'

2017 10-2-1415

HEFFER RD,

