

HOWARD COUNTY HEALTH DEPARTMENT  
BUREAU OF ENVIRONMENTAL HEALTH  
WELL & SEPTIC PROGRAM  
TEL: (410)313-1771 FAX: (410)313-2648

Information Form for the Installation of the Well Pump, Pitless Adapter, and Supply Piping

NOTE: The installer is responsible for requesting an inspection prior to 9 am on the day of the desired inspection. No work is to be covered until approved by the Health Department. All installations must comply with the National Standard Plumbing Code (NSPC, as amended locally) and COMAR 26.04.04 (MD Well Construction Regulations). Submission of a complete form is required prior to Use and Occupancy approval.

Company Name: CASTLEHAY WELL & PUMP  
9265 BROWN CHURCH RD  
MT AIRY, MD 21771 Telephone #: 301-831-5170  
Address: 301-831-5170

(Must circle one) Licensed Plumber Licensed Well Driller Licensed Well Pump Installer **X**  
License # and name of individual responsible for the field installation:

Name (Print): Jerry A. Miller III License# WR 0074

\*A licensed individual must perform the actual installation. Apprentices must be under the supervision of a licensed journeyman or master plumber, pump installer or well driller. Licenses may be subjected to field verification. Unlicensed individuals may be reported to the appropriate licensing agency.

Name of Property Owner: Richard Butler Telephone #: \_\_\_\_\_  
Subdivision: \_\_\_\_\_ Lot #: \_\_\_\_\_ Well Tag #: HO -

Site Address: 16062 A.E. Hollin Rd.  
Woodbine, MD.

Submersible Pump Data Pitless Adapter Well Cap and Electric Conduit  
Make: Goulds Make: Martinson Two piece watertight cap: \_\_\_\_\_  
Model #: 7660540C Model#: B-10X Screened, vented well cap:   
Pump Capacity 10 GPM Depth: 3 1/2 (36" min) Cap secured to casing:   
Well Yield: \_\_\_\_\_ GPM NSF/WSC approved: \_\_\_\_\_ Conduit min 18" B.G.:   
Depth of well encountered at time of pump installation: \_\_\_\_\_ (feet) Conduit secured to well cap:   
If pump capacity exceeds well yield, a low water cut off switch is required by NSPC 1990 Section 17.8.4  
Torque arrestors, Cable guards, or other acceptable method used- Must circle one  
Safety rope, if used, attached to brass rope adapter or other acceptable method inside of well casing

Piping to house House Connection  
Type: PE PVC sleeve to undisturbed soil at wall penetration: yes  
PSI: 200 (160 psi min) Length of sleeve (5' minimum from foundation): 5ft.  
Depth of supply line: 3 1/2 (36" min) Sleeve sealed properly: yes

The water supply line is required to be at least ten feet from the septic tank, pump chamber, sewage piping, distribution box, drainfields, and sewage reserve area. If this cannot be accomplished, contact this office for approval prior to installation.

Signature of company representative responsible for installation: Jerry A. Miller III date: 9/24/13

For Health Department Use Only - Not to be completed by Installer

Date Insp. Requested: \_\_\_\_\_ Date Insp. Approved: \_\_\_\_\_ Inspector: RB 10/22/2013  
Inspection Data: Pitless adapter watertight & water supply line at least 36" below grade   
Two piece cap installed and attached to casing securely   
Elec. conduit extends at least 18" below grade/attached to cap properly   
Safety rope not outside of well cap/casing   
Correct well tag attached properly and casing 8" above finished grade   
Water supply line sleeved adequately at house connection No Tag  
Adequate grout observed below pitless adapter Connected to Existing  
None Seen