



Bureau of Environmental Health
 8930 Stanford Boulevard, Columbia, MD 21045
 Main: 410-313-2640 | Fax: 410-313-2648
 TDD 410-313-2323 | Toll Free 1-866-313-6300
www.hchealth.org
 Facebook: www.facebook.com/hocohealth

Maura J. Rossman, M.D., Health Officer

RECEIPT DATE: 10/30/18 **ONSITE SEWAGE DISPOSAL SYSTEM**

P 564054

INSTALLATION APPROVAL DATE: 1/22/19 *(K.M.)*

PERMIT

A _____

SEWER HOUSE CONNECTION

PROPERTY ADDRESS: 5046 Crape Myrtle Court

SUBDIVISION: Walnut Creek LOT: 150 TAX ID: 05-598903

CONTRACTOR: Craftmark Homes EMAIL: jpavlik@craftmarkhomes.com

CONTRACTOR ADDRESS: 1355 Beverly Road Suite 300, McClean VA, 22101 PHONE: 703-932-0573

PROPERTY OWNER: NVR Inc. EMAIL: _____

OWNER ADDRESS: 9720 Patuxent Woods Road, Columbia, MD 21046 PHONE: 410-379-5956

NUMBER OF BEDROOMS: 5 CONNECTED TO PUBLIC WATER: YES NO

LOCATION:	INSTALL 4" SEWER LINE PER APPROVED SITE PLAN.
NOTES:	

ISSUED BY: Robert Freemon ISSUE DATE: 10/30/2018 EXPIRATION DATE: 10/30/2019

NOTE: HOWARD COUNTY BUREAU OF UTILITIES APPROVAL OF GRINDER PUMP INSTALLATION IS REQUIRED PRIOR TO SEPTIC PERMIT APPROVAL

NOTE: CONTRACTOR MUST SCHEDULE AN INSPECTION AND GAIN APPROVAL OF ALL COMPONENTS PRIOR TO COVERING

NOTE: AN ELECTRICAL PERMIT IS REQUIRED FOR INSTALLATION OF ANY ELECTRICAL COMPONENTS OF THE SYSTEM

**NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.
 PERMITTEE RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT.
 CALL 410-313-1771 FOR INSPECTION OF SEPTIC SYSTEM.**

Wolf, Kevin

From: Bozzell, Duane
Sent: Wednesday, January 16, 2019 7:06 AM
To: Miscbilling
Cc: Hart, Amy; Rocco, Anthony; Martin, Sharhonda; Williams, Jeffrey; Bozzell, Duane; Bernard, Dana; Wolf, Kevin; Collins, Sarah; jpavlik@CraftmarkHomes.com
Subject: U&O Release 5045 Crape Myrtle ct lot150

On the morning of 1-15-2019 observed the start-up of a Sewage Grinder Pump at the Walnut Creek Shared Septic System:
Contract#

Lot #150
5046 Crape Myrtle ct.
Ellicott City MD. 21043
The Sewage Grinder Pump test was successful; the Bureau of Utilities releases its hold on this property for U&O.

Thank You.

Duane Bozzell
J.N.C.COM
DPW-Bureau of utilities
Phone: (410)313-4900
Fax: (410)313-4989

