

CASSELL TESTING, INC.

ENVIRONMENTAL SAMPLING AND TESTING
10940 BEAVER DAM ROAD, HUNT VALLEY, MD 21030-2211
(410) 252-7742

REPORT DATE: Nov 7, 2002

County: Howard

Lab Number: 02-5584

Sample iced: Yes
Residual Cl₂ <0.1 mg/L: Yes

cc: County Health Dept. Yes

CERTIFICATE OF ANALYSIS

Maryland State Certified Water Quality

Laboratory No. 115

REQUESTER:

Williamsburg Group LLC
P.O. Box 1018
Columbia, Maryland 21044
Attn: Accounts Receivable

Property Sampled: U&O: 2935 New Rover Road

Station Sampled: Powder room tap

Date/Time Sampled: Nov 6, 2002 11:00 am

Owner, Telephone No.:

Subdivision Name: Friendship Lakes

Building Permit No.: B00135873

Well Number: HD-94-3025

Tax Map #:

Parcel #:

Sampler: 67246P

Lot Number: 12

Observation: 2-Piece Cap
Satisfactory

RESULTS OF ANALYSIS:

PARAMETER	RESULT	METHOD	*MCL/**SMCL	
Nitrate	1.0 mg/L as N	SM 4500D	*10 mg/L as N	Pass
Turbidity	<1.0 NTU	EPA 180.1	*10 NTU	Pass
pH	6.6 Units	EPA 150.1	**6.5-8.5 Units	
Sand	Negative		Negative	
Total Coliform (18 Hour Test)	Absent	SM 9223B	*Absent	SAFE

Heather R. Beam
Heather R. Beam

*MCL = Maximum Contamination Level

**SMCL = Secondary Maximum Contamination Level