



DEPARTMENT OF HEALTH AND MENTAL HYGIENE  
ENVIRONMENTAL HEALTH ADMINISTRATION BALTIMORE, MD. 21201

**SEWERAGE PERMIT**

No. 72-25-0613

Date September 7, 1972

Page 1 of 3

This is to certify that the Maryland State Department of General Services  
is permitted to construct a temporary sewage treatment plant  
together with all appurtenances, at the Maryland School for the Deaf, Columbia  
campus, Howard County  
in accordance with application from the Maryland State Department of General Services  
dated August 15, 1972  
and plan and specifications received by the Department of Health and Mental Hygiene on  
August 17, 1972, entitled in part:

Sewage Treatment Plant  
Project Number -YAH-2-702  
Drawings No. 1 thru 5 of 5, 6/30/72

and

Specifications

**THIS PERMIT IS ISSUED SUBJECT TO ALL OF THE FOLLOWING  
PROVISIONS AND CONDITIONS HEREINAFTER SET FORTH:**

1. This permit does not certify to the structural adequacy of the various structures involved.
2. This permit becomes null and void three years from the date of issue, if not specifically extended, unless the work herein approved shall have been completed and placed in operation on or before said date.
3. This permit is not transferable.


 DEPARTMENT OF HEALTH AND MENTAL HYGIENE  
 ENVIRONMENTAL HEALTH ADMINISTRATION BALTIMORE, MD. 21201

## SEWERAGE PERMIT

No. 72-25-2633Date September 7, 1972

Page 2 of 3

4. This permit is issued on the basis of the following design criteria presented in the approved construction plans and specifications:

- a. Daily Flow: 0,017 mgd.
- b. Population Equivalent: Residents 83 and Non-Residents 246
- c. B.O.D. (Biochemical Oxygen Demand) of the final effluent: As approved by Point of Discharge  
 (1) max. 35 mg/l, and  
 (2) max. 5 lbs/day.
- d. Suspended Solids of the final effluent: As approved by Point of Discharge  
 (1) max. 32 mg/l, and  
 (2) max. 4 lbs/day.

If during the use of the facilities covered by this permit the public health is endangered or violated or the Water Quality Standards are endangered or violated, the Department of Health and Mental Hygiene (hereinafter called the Department) may take, or require, such corrective action as is consistent and appropriate with the law.

5. In accordance with the Regulations issued under Section 406A, Article 43, of the Annotated Code of Maryland, the sewerage facility covered by this Permit is classified as \_\_\_\_\_.
6. Upon the approval of the construction plans and specifications and the issuance of a permit by the Department, it is and shall remain the sole and continued responsibility of the Owner, his heirs, assigns, successors, his authorized agents or representatives, for the design and operations of the facilities for the intended purposes, and to construct, operate and continuously maintain in a satisfactory manner at all times the total facility in compliance with the laws, rules, regulations and requirements of the State of Maryland.
7. The Department in issuing this permit has relied upon the statements and representations made and presented by the Owner and his authorized agents or representatives.
8. If any changes, additions, or deletions are necessary at any time, new or revised plans and specifications must be submitted, and a new permit, after review, may be required of the Department before the construction of such major changes, additions, or deletions. After completion of the work a certified copy of the plans in full, showing the work as built, shall be filed with the Department for permanent record.

State of



Maryland

DEPARTMENT OF HEALTH AND MENTAL HYGIENE  
ENVIRONMENTAL HEALTH ADMINISTRATION BALTIMORE, MD. 21201

SEWERAGE PERMIT

No. 72-25-0013

Date September 7, 1972

Page 3 of 3

9. The Owner shall employ certified plant personnel and shall be responsible for the submission to the Department of monthly plant operating reports in the form approved by the Department.
10. Upon completion of the facilities, the Owner shall submit in writing a statement certifying that the facilities have been constructed in accordance with approved plans and specifications. The Owner shall further furnish at least ten (10) days notice to the Department indicating the date when the facility covered by this permit is expected to be placed into operation.
11. The Owner shall immediately notify the Department whenever a discharge of untreated or partially treated sewage has occurred and shall, within 24 hours of such discharge, furnish to the Department such information as to the cause, frequency, quality, duration and volume of such discharge. Further, the Owner shall, as soon as possible but no later than 30 days thereafter, submit to the Department a plan and a time schedule for the elimination and prevention of future discharges of untreated or partially treated sewage.
12. When the monthly average of any one or more of the design criteria enumerated in Paragraph 4 reaches seventy-five percent (75%) for a period of three (3) consecutive months, the Owner shall submit to the Department within ninety (90) days an analysis of projected loadings and a program for increasing plant capacity in order to provide satisfactory treatment for waste loads exceeding the design criteria enumerated in Paragraph 4.

As witness the signatures of authorized officials of the Department of Health and Mental Hygiene.

*Howard G. Chaney*

Director, Environmental Health Administration

*W. L. ...*  
Chief, Division of Water and Sewerage