

Bureau of Environmental Health
 8930 Stanford Boulevard, Columbia, MD 21045
 Main: 410-313-2640 | Fax: 410-313-2648
 TDD 410-313-2323 | Toll Free 1-866-313-6300
www.hchealth.org
 Facebook: www.facebook.com/hocohealth

Maura J. Rossman, M.D., Health Officer

RECEIPT DATE: 6/7/17 **ONSITE SEWAGE DISPOSAL SYSTEM** P 561408

APPROVAL DATE: 6/15/17 (KMW) **PERMIT: MINOR REPAIR** A _____

PROPERTY ADDRESS: 13358 Grinstead Court

SUBDIVISION: Annandale LOT: 9 TAX ID: _____

CONTRACTOR: Fogle's Septic Clean Inc. EMAIL: kim@foglesinc.com

CONTRACTOR ADDRESS: 580 Obrecht Road, Sykesville, MD 21784 PHONE: 410-795-5670

PROPERTY OWNER: JTM LLC EMAIL: _____

OWNER ADDRESS: _____ PHONE: 301-775-1956

SEPTIC TANK SIZE (GALLONS): Existing PUMP CHAMBER CAPACITY (GALLONS): N/A PUMP SIZE: N/A

NUMBER OF BEDROOMS: 4 HOUSE SQ. FT. _____ APPLICATION RATE: _____

DISTRIBUTION SYSTEM: GRAVITY FED LOW PRESSURE DOSED

TRENCHES:	LINEAR FEET REQUIRED: _____	INLET DEPTH: _____
	TRENCH WIDTH: _____	MAXIMUM BOTTOM DEPTH: _____
	MINIMUM SPACE BETWEEN TRENCHES: _____	EFFECTIVE AREA BEGINNING DEPTH: _____
LOCATION:	TO BE STAKED BY SANITARIAN DURING PRE-CONSTRUCTION INSPECTION.	
NOTES:	<p>Pump/collapse existing Drywell. Run ^{new} pipe (sch. 40) from ex. s.p. to ex. trench. obs. pipe to be installed @ trench ends. New baffles to be installed on tank.</p> <p>* Please note this trench does not constitute for full system</p>	


ISSUED BY: K. Wolf ISSUE DATE: 6/15/17 EXPIRATION DATE: 6/15/18 ^{design permit}

- NOTE: CONTRACTOR MUST SCHEDULE A PRE-CONSTRUCTION INSPECTION PRIOR TO BEGINNING ANY INSTALLATION
- NOTE: CONTRACTOR MUST SCHEDULE AN INSPECTION AND GAIN APPROVAL OF ALL COMPONENTS PRIOR TO COVERING
- NOTE: STONE MUST BE APPROVED BY HEALTH DEPARTMENT AND GRAVEL TICKET MUST BE AVAILABLE FOR REVIEW.
- NOTE: WATERTIGHT SEPTIC TANKS REQUIRED
- NOTE: ALL PARTS OF SEPTIC SYSTEM SHALL BE AT LEAST 100 FEET DOWNGRADIENT FROM ANY WATER WELL
- NOTE: MANHOLE RISERS REQUIRED ON ALL SEPTIC TANKS AND PUMP CHAMBERS
- NOTE: AN ELECTRICAL PERMIT IS REQUIRED FOR INSTALLATION OF ANY ELECTRICAL COMPONENTS OF THE SYSTEM
 - ELECTRICAL PERMIT ISSUED E N/A
- NOTE: THE HCHD DOES NOT WARRANTY ANY SYSTEM AND CANNOT GUARANTEE THE PERFORMANCE OF THIS SYSTEM AS DESIGNED. BY ACCEPTING THIS PERMIT, THE OWNER AND/OR APPLICANT ACKNOWLEDGE THAT THE SPECIFICATIONS DETAILED IN THIS DESIGN ARE ONE POSSIBLE OPTION AND THAT THE HCHD WILL REVIEW OTHER PROPOSALS. YOU HAVE THE OPTION TO SEEK THE ADVICE OF A QUALIFIED DESIGN CONSULTANT OR PROFESSIONAL ENGINEER FOR FURTHER GUIDANCE.
- NOTE: MDE RECOMMENDS SEPTIC TANKS, BAT, AND OTHER PRETREATMENT UNITS BE PUMPED AT A FREQUENCY ADEQUATE TO ENSURE THAT SOLIDS ARE NOT DISCHARGED TO THE DISPOSAL AREA

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.
PERMITTEE RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT.
CALL 410-313-1771 TO SCHEDULE INSPECTIONS.

NOT TO SCALE

100



Carlinwood Ct.
ROAD NAME

TRENCH/DRAINFIELD DATA

WIDTH _____ INLET _____ BOTTOM _____

NUMBER OF TRENCHES _____

TOTAL LENGTH _____

ABSORPTION AREA _____

DISTRIBUTION BOX LEVEL _____

DISTRIBUTION BOX BAFFLE _____

DISTRIBUTION BOX PORT _____

SEPTIC TANK DATA

SEPTIC TANK 1 LEVEL _____

MANUFACTURER _____

CAPACITY _____ GAL

SEAM LOC _____

TANK LID DEPTH _____

BAFFLES _____

BAFFLE FILTER _____

MANHOLE LOC _____

6" PORT LOC _____

WATERTIGHT TEST _____

SLOTTED _____

DATE ON LID _____

PUMP/SEPTIC TANK LEVEL _____

MANUFACTURER _____

CAPACITY _____ GAL

SEAM LOC _____

TANK LID DEPTH _____

BAFFLES _____

BAFFLE FILTER _____

MANHOLE LOC _____

6" PORT LOC _____

WATERTIGHT TEST _____

SLOTTED _____

DATE ON LID _____

PRE-CONSTRUCTION:

INSTALLATION: 6/15/17 (pm) Contractor installed new plumbing sch 40
 from ex. s.t. to ex. trench. Ex. DW. pumped and
 collapsed. OK to con work (pm)

FINAL INSPECTOR J. Wolf DATE OF APPROVAL 6/15/17



Bureau of Environmental Health

8930 Stanford Boulevard, Columbia, MD 21045

Main: 410-313-2640 | Fax: 410-313-2648

TDD 410-313-2323 | Toll Free 1-866-313-6300

www.hchealth.org

Facebook: www.facebook.com/hocohealth

Twitter: HowardCoHealthDep

Dr. Maura J. Rossman, M.D., Health Officer

INFORMATION FORM - SEPTIC SYSTEM REPAIR/UPGRADE

Reason for Request:

- Failing System
System relocation for proposed addition
System upgrade for proposed addition
Inadequate treatment zone
Collapsed septic tank
Collapsed drywell

Has the septic tank been pumped within the last month?

- Yes
No

Was a visual inspection of the septic tank and/or drain fields conducted?

- Yes Explain observations: Failing drywell
No

Existing system design

- Drywell
Trench
Mound
Unknown
Other

Was a visual inspection of the sewage line conducted?

- Yes
Blockage leading to the tank
Yes Explain
No
Blockage leading to the field
Yes Explain
No

Is discharge surfacing on the ground?

- Yes
No

Additional Comments:

*For REPAIRS, are the owners proposing, or do they plan to add in the future, any additions or modifications to the property, i.e. pools, living space additions, garages, etc? This information must be disclosed at the time of this application.

Septic Contractor: Fogle's Septic Clean Contractor's Phone: 410-795-5670
Contractor's Address: 580 Oberholt Rd 21784

Property Address: 13358 Grinstead Ct County file:
Subdivision: Annapole Lot: 9 Year Built: 1981
Owner's Name: JTM LLC Owner's Phone: 301-775-1956

Name of previous owners: Richard Graham Existing bedrooms: 4
Proposed bedrooms:

Has this request been previously discussed with a Sanitarian? (Name):
Public Sewer available/nearby:

*A Sanitarian will be in contact within three business days, depending upon the urgency of the situation, to coordinate the scheduling/review of the repair or upgrade.

*Prior to scheduling inspections, scaled plans should be submitted to clarify the nature of the addition.
Print out a copy of Real Property Data via Dept. of Taxation website Indexed file found
If public sewer may be nearby, verify whether sewer is technically "available" through the Bureau of Engineering.
If sewer is available and the property is within the Metropolitan District, connection to sewer is required; if the owner believes reason for exemption exists, the owner should justify the request in writing.
If soil/site conditions are limited and sewer and/or Metro District status is not conducive to connection, the Sanitarian may recommend pursuit of Emergency Sewer Extension or Emergency Metro District Inclusion. The Owner should contact the Bureau of Utilities for details.

No permit is to be issued nor inspection to be scheduled without prior fee collection at the office unless an emergency situation exists. The contractor is to notify office of the emergency situation as soon as possible.

FILE INQUIRY NOTES

13358 Grinstead Ct.

DATE	RESULTS OF REVIEW FOR FILE
6/15/17	<p>onsite for pipe repair. spent good amount of time digging up ex system. Daywell full of solid to the top. 51' trench w/ daywell exposed @ beginning and end. Dry, stone clean no bio mat. owner contacted to confirm how they want to proceed. (ie. abandon daywell connect to trench or percolator for new system).</p> <p>... Owner finally contacted (11:30-2pm) to pump/collapse ex. daywell, connect new plumbing (sch 40) to ex. trench. Add obs. pipe @ end. Add outlet baffle to ex. s.t w/ meshlike ribs (per contractor).</p>
	<p>→ Refund of \$330.00 - \$55.00 (for other repair) to be issued to Foght's upon request.</p>

(See pictures in file dated 6/15/17)

onsite for pipe repair. spent good amount of time digging up ex system. Daywell full of solid to the top. 51' trench w/ daywell exposed @ beginning and end. Dry, stone clean no bio mat. owner contacted to confirm how they want to proceed. (ie. abandon daywell connect to trench or percolator for new system).

... Owner finally contacted (11:30-2pm) to pump/collapse ex. daywell, connect new plumbing (sch 40) to ex. trench. Add obs. pipe @ end. Add outlet baffle to ex. s.t w/ meshlike ribs (per contractor).

→ Refund of \$330.00 - \$55.00 (for other repair) to be issued to Foght's upon request.

6/15/17

(kmw)



→ From
old Drywell
abandoned
(6/15/17)
PM

start of 51' trench

6/15/17

(Kane)



End of 51' trench
clean stone, no bit mat
or
water



HOWARD COUNTY HEALTH DEPARTMENT

61408

DATE 6/7/17

Received From

Taylor Septic Clean

PHONE # 410 795 2670

For Rec Repair 13358 Gunstead Court

- CASH
- CHECK

NO.

51030

Three hundred thirty _____ 00/100 Dollars

\$ 330.00

Received By

[Signature]