



Bureau of Environmental Health

8930 Stanford Boulevard, Columbia, MD 21045

Main: 410-313-2640 | Fax: 410-313-2648

TDD 410-313-2323 | Toll Free 1-866-313-6300

www.hchealth.org

Facebook: www.facebook.com/hocohealth

Twitter: HowardCoHealthDep

Maura J. Rossman, M.D., Health Officer

MEMORANDUM

TO: Juanita King

FROM: Jeff Williams

RE: Refund, receipt # 64828 refunding \$165 at 13540 Frederick Road

DATE: June 18, 2019

Please submit the paperwork for a refund of \$165 to Streaker Construction, who paid \$165 for repair perc testing at 13540 Fredrick Rd as part of receipt #64828.

During the site inspection, it was discovered that the septic problem could be solved via a minor septic repair, which incurs a fee of \$55, and that fee was paid separately. No work was performed by the Health Department as part of this application.

FOUNTAIN VALLEY ANALYTICAL LABORATORY, INC.

1413 Old Taneytown Rd. Westminster, MD (410) 848-1014 (410) 876-4554 FAX (410) 848-0298

REPORT OF ANALYSIS

Laboratory ID #: 131521 Account #: 1933
Reference: Belvedere Estates (Model) Company: Fogles Well Pump & Treatment
Location: 13711 Tergeo Drive Requested By: Dave Fogle
West Friendship, MD 21794 Source: Well Water
Date/ Time Collected: 7/22/2019 1115 Site: Kitchen Sink Tap
Date/Time Rec'd: 7/22/2019 1150 Treatment: None
Chlorine ppm: Free: ND Total: ND pH: 6.3
Collected By: J. Evans 7411JE Well #: HO-17-0010

PARAMETERS	RESULTS	UNITS	REFERENCE	METHOD	DATE/TIME/ANALYST
Bacteria, Coliform, Total, MPN	34.4	MPN/ 100 ml	<1.0	SM20 9223B	7/23/2019 / 1030 / RER
Bacteria, E. coli, MPN	<1.0	MPN/ 100 ml	<1.0	SM20 9223B	7/23/2019 / 1030 / RER

NOTES

- 1 MPN/ 100 ml = Most Probable Number [of viable bacteria] per 100 ml of sample.
- 2 Results less than or within the reference range are considered satisfactory and within potable water limits at the time of sampling.
- 3 Sample collected by client, analyzed as received
- 4 ND:None Detected
- 5 Visual well check: Sealed, vented cap
- 6 pH and Chlorine level tested in lab (pH tested after recommended holding time)

Reason for Test : Use & Occupancy

Building Permit # : 19000812

Date Reported: 7/23/2019