

# APPLICATION

SEWAGE DISPOSAL TESTING

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

ELLICOTT CITY

DISTRICT 3

DATE 8/3/71

A 16191

P \_\_\_\_\_

TO: THE COUNTY HEALTH OFFICER  
ELLICOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TESTS IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER Edwin W. Grimes

ADDRESS Route 144, West Friendship, Md. PHONE 489-4837

PROPERTY LOCATION:

SUBDIVISION NON 72113 LOT NO. \_\_\_\_\_

ROAD AND DESCRIPTION Route 144 - pass the corner of Rt. 144 & Rt. 32 going West  
1st house on right after passing the corner

OCCUPANT \_\_\_\_\_ PHONE \_\_\_\_\_

PERSON TO CONSTRUCT SYSTEM \_\_\_\_\_

ADDRESS \_\_\_\_\_ PHONE \_\_\_\_\_

SIZE OF LOT 3 or 4 acres TYPE BLDG. Existing house  
3 or 4 NUMBER OF BEDROOMS

IF NOT SINGLE RESIDENCE DESCRIBE \_\_\_\_\_

SIGNATURE OF APPLICANT Edwin W. Grimes

APPROVED BY \_\_\_\_\_ FOR \_\_\_\_\_ DATE \_\_\_\_\_  
(KIND OF SYSTEM)

REJECTED BY \_\_\_\_\_ FOR \_\_\_\_\_ DATE \_\_\_\_\_  
(KIND OF SYSTEM)

HOLD PENDING FURTHER TESTS \_\_\_\_\_ DATE \_\_\_\_\_

REASONS FOR REJECTION OR HOLDING \_\_\_\_\_

(what should be returned to applicant)

# THIS IS NOT A PERMIT



# APPLICATION

A 16191

SEWAGE DISPOSAL TESTING

P \_\_\_\_\_

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

ELLICOTT CITY

DISTRICT 3

DATE 8/3/71

*1000 gal septic tank  
water tight sump, sewerage effluent pump  
Minimum → 450 sq ft absorbent area  
4 ft grave at maximum depth of 5 feet.*

*Recorded  
8/11/71 cancelled  
9/1/71*

*9/1/71  
1:30*

TO: THE COUNTY HEALTH OFFICER  
ELLICOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TESTS IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER Edwin W. Grimes

ADDRESS Route 144, West Friendship, Md. PHONE 489-4837

PROPERTY LOCATION:

SUBDIVISION \_\_\_\_\_ LOT NO. \_\_\_\_\_

ROAD AND DESCRIPTION Route 144 - pass the corner of Rt. 144 & Rt. 33 going West  
1st house on right after passing the corner

OCCUPANT \_\_\_\_\_ PHONE \_\_\_\_\_

PERSON TO CONSTRUCT SYSTEM \_\_\_\_\_

ADDRESS \_\_\_\_\_ PHONE \_\_\_\_\_

SIZE OF LOT 3 or 4 acres TYPE BLDG. Existing house  
3 or 4  
NUMBER OF BEDROOMS \_\_\_\_\_

IF NOT SINGLE RESIDENCE DESCRIBE \_\_\_\_\_

SIGNATURE OF APPLICANT *Edwin W. Grimes*

APPROVED BY \_\_\_\_\_ FOR \_\_\_\_\_ DATE \_\_\_\_\_  
(KIND OF SYSTEM)


REJECTED BY \_\_\_\_\_ FOR \_\_\_\_\_ DATE \_\_\_\_\_  
(KIND OF SYSTEM)

HOLD PENDING FURTHER TESTS \_\_\_\_\_ DATE \_\_\_\_\_

REASONS FOR REJECTION OR HOLDING Hold for Mr Wine to discuss  
system. (Property sold or not.)

To tip Mr. Glasser so he can see perc testing. Mr. Glasser  
approved repair described above. *11/22*

# THIS IS NOT A PERMIT



INDICATE NORTH. - NAME ADJOINING ROADWAY AS BASE LINE.

DATE	TEST NO.	DEPTH	PRE-WET		TEST - 1" DROP		TIME
			START	STOP	START	STOP	
	①						
	②						
10/2/76	①	5'	206	208'	208	210	2 min
			210	212			

SOIL AUGER FINDING \_\_\_\_\_

TESTED BY \_\_\_\_\_

REMARKS

1000 gal tank

1.15

September 20, 1971

Mr. Lee Bradley  
State Roads Commission  
4093 St. Johns Lane  
Ellicott City, Maryland

Dear Sir:

A standard percolation test was run on the property of  
Edwin W. Grimes, Route 144, West Friendship, Maryland. The property  
failed to pass the percolation test on September 1, 1971.

Very truly yours,

Palmer F. Wine, Director  
Environmental Health

PFW:jx