

Maura J. Rossman, M.D., Health Officer

Information Form for the Installation of the Well Pump, Pitless Adapter, and Supply Piping

NOTE: The installer is responsible for requesting an inspection prior to 9 am on the day of the desired inspection. No work is to be covered until approved by the Health Department. All installations must comply with the National Standard Plumbing Code (NSPC, as amended locally) and COMAR 26.04.04 (MD Well Construction Regulations). Submission of a complete form is required prior to Use and Occupancy approval.

Company Name: Foale's Well Pump & Water Treatment, LLC Telephone #: 410 795 5670
 Address: 5300 Abrecht Rd
Sykesville, MD 21784

Must circle one: Licensed Plumber / Licensed Well Driller / Licensed Well Pump Installer

License # and name of individual responsible for the field installation:
 Name (Print): David C Foale License# MSD2226

*A licensed individual must perform the actual installation. Apprentices must be under the supervision of a licensed journeyman or master plumber, pump installer or well driller. Licenses may be subjected to field verification. Unlicensed individuals may be reported to the appropriate licensing agency.

Name of Property Owner: Chris Curley Telephone #: _____
 Subdivision: Patrick Family Lot #: 2 Well Tag #: HO-17-0393 ✓
 Site Address: 1604 Florence Rd
Mt Airy, MD 21797

Submersible Pump Data	Pitless Adapter	Well Cap and Electric Conduit
Make: <u>Grundfos</u>	Make: <u>Campbell +</u>	Two piece watertight cap: <u>✓</u>
Model #: <u>ES6007-180</u>	Model#: <u>NA</u>	Screened, vented well cap: <u>✓</u>
Pump Capacity: <u>15</u>	GPM Depth: <u>36"</u> (36" min)	Cap secured to casing: <u>✓</u>
Well Yield: <u>3</u>	GPM NSF/WSC approved: <u>✓</u>	Conduit min 18" B.G.: <u>✓</u>
Depth of well encountered at time of pump installation: <u>500</u> (feet)		Conduit secured to well cap: <u>✓</u>
If pump capacity exceeds well yield, a low water cut off switch is required by NSPC 1990 Section 17.8.4		
Must circle one: Torque arrestors / Cable guards / Other acceptable method used		
Safety rope, if used, attached to brass rope adapter or other acceptable method <u>inside of well casing</u> <u>NA</u>		

Piping to house	House Connection
Type: <u>1" DWV pipe</u>	PVC sleeve to undisturbed soil at wall penetration: <u>✓</u>
PSI: <u>200</u> (160 psi min)	Length of sleeve (5' minimum from foundation): <u>16'</u>
Depth of supply line: <u>36"</u> (36" min)	Sleeve sealed properly: <u>✓</u>

The water supply line is required to be at least ten feet from the septic tank, pump chamber, sewage piping, distribution box, drainfields, and sewage reserve area. If this cannot be accomplished, contact this office for approval prior to installation.

[Signature] _____
 Signature of company representative responsible for installation date 6/11/2021

For Health Department Use Only - Not to be completed by Installer

Date Insp. Requested: <u>6/2/21</u>	Date Insp. Approved: <u>6/2/21</u>	Inspector: <u>AM</u>
Inspection Data:	Pitless adapter watertight & water supply line at least 36" below grade	<u>✓</u>
	Two piece cap installed and attached to casing securely	<u>✓</u>
	Elec. conduit extends at least 18" below grade/attached to cap properly	<u>✓</u>
	Safety rope not outside of well cap/casing	<u>✓</u>
	Correct well tag attached properly and casing 8" above finished grade	<u>✓</u>
	Water supply line sleeved adequately at house connection	<u>✓</u>
	Adequate grout observed below pitless adapter	<u>✓</u>

(Revised form 10/24/2018)