

# HOME LAND

## L A B S

9106 Philadelphia Road, Suite 106  
 Rosedale, MD 21237  
 Phone 443.505.8375  
 lab@homelandhealthyhomes.com  
 State Certified Water Quality Lab 353

108 Old Solomons Island Road, Suite 12  
 Annapolis, MD 21401  
 Phone 443.505.8375  
 lab@homelandhealthyhomes.com  
 State Certified Water Quality Lab 106

3430 Rockefeller Court  
 Waldorf, MD 20602  
 Phone 443.505.8375  
 lab@homelandhealthyhomes.com  
 State Certified Water Quality Lab 139

### Certificate of Analysis

Date Reported: 08/27/2020

Hague Quality Water  
 814 E. College Parkway  
 Annapolis, MD 21409

Date & Time Received: 08/25/2020 14:05

*This report is the sole property of Hague Quality Water. Any questions about the report MUST be directed to Hague Quality Water at (410) 757-2992.  
 Home Land Labs is not at liberty to discuss this report without written consent from Hague Quality Water.*

**Sample Number:** 191622-01      Sample Time: 08/24/20 14:30      Preservation: Ice  
**Location:** 13484 Open Space Ct      Chlorine Residual: 0.0      Sampler: TEdwards8309TE (Exp. 5/14/2022)  
 Highland, MD 20777      Field pH: 7.3      Sample Point: Pressure Tank

Parameter	Method	Result	Pass/Fail or Acceptable/High	RL	Units	MCL / SMCL	Date of Analysis	Analyst
Iron, Total	H 8008	3.90	High	0.05	mg/l	0.3	08/26/2020	DLB-139
Bacteria-Total Coliform	Colitag Test	Absent	Pass	1	Per/100ml	Present	08/26/2020	MAV-106
Bacteria-E.coli	Colitag Test	Absent	Pass	1	Per/100ml	Present	08/26/2020	MAV-106
Nitrate + Nitrite as N	EPA 353.2	Not Detected	Pass	0.5	mg/l	10	08/26/2020	DLB-139
Turbidity	EPA 180.1	26.1	High	0.5	NTU	10	08/24/2020	MAV-106

Approved By Kevin Barnata  
 Lab Director

Chain of Custody Form

# HOME LAND

LABS



191622 Date Due:  
 Client: Hague Quality Water  
 Project:

9106 Philadelphia Road, Suite 106  
 Rosedale, MD 21237  
 (443) 505-8375  
 MD Lab # 353

108 Old Solomons Island Road, Suite L2  
 Annapolis, MD 21401  
 (410) 224-4304  
 MD Lab # 106

3430 Rockefeller Court  
 Waldorf, MD 20602  
 (410) 224-4304  
 MD Lab # 139

Client Name: HAGUE

---

Email Address: TESW@HAGUEWATEROFMD.COM

---

Phone Number: 410-757-2992

---

Property Address: 13484 OPEN SPACE CT

---

HIGHTOWN, MD 20777

---

**Field Collection Information**

Sampler Name:	<u>TIM EDWARDS</u>
Sampler ID #:	<u>TEB309</u>
Date and Time Sampled:	<u>8/24/2020 2:30pm</u>
Well Tag Number:	

Field pH:	<u>7.3</u>
Field Chlorine (mg/L):	<u>0</u>
Sand:	<u>None</u>
Clarity:	<u>Average</u>

**Well Casing and Cap Condition**

Height Above Grade:	Cap Type:	Casing:	Conduit:
---------------------	-----------	---------	----------

Sample Point: <u>PRESSURE TANK</u>	Water Conditioning: <u>NONE</u>
---------------------------------------	------------------------------------

**Requested Testing: (Please check all that apply)**

- Potability (Bacteria, Nitrates, pH, Turbidity)
- FHA/VA (Bacteria, Nitrates, Nitrites, pH, Turbidity, Lead and Iron)
- Bacteria
- Lead
- Nitrates
- Iron
- Gross Alpha
- Saltwater Intrusion
- Arsenic
- Cadmium
- Fluoride
- Pesticides
- VOC
- Hardness
- Other: \_\_\_\_\_
- Other: \_\_\_\_\_
- Other: \_\_\_\_\_
- Other: \_\_\_\_\_
- Other: \_\_\_\_\_
- Other: \_\_\_\_\_

List rush samples below  
 \*Refer to table for rush turnaround times and fees\*

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

**Release Signatures**

Released By: [Signature] Date/Time: 8/25/2020 1:39

Released By: \_\_\_\_\_ Date/Time: \_\_\_\_\_

Released By: \_\_\_\_\_ Date/Time: \_\_\_\_\_

Received in lab by: [Signature] Date/Time: 8/25/2020 14:05