



**Bureau of Environmental Health**  
 8930 Stanford Boulevard, Columbia, MD 21045  
 Main: 410-313-2640 | Fax: 410-313-2648  
 TDD 410-313-2323 | Toll Free 1-866-313-6300  
[www.hchealth.org](http://www.hchealth.org)  
 Facebook: [www.facebook.com/hocohealth](http://www.facebook.com/hocohealth)

Maura J. Rossman, M.D., Health Officer

RECEIPT DATE: N/A

**ONSITE SEWAGE DISPOSAL SYSTEM**

P N/A

INSTALLATION APPROVAL DATE: 11/9/2015

**PERMIT  
MINOR REPAIR**

A \_\_\_\_\_

PROPERTY ADDRESS: 14331 Bensworth Way

SUBDIVISION: Edgewood Farm Phase II LOT: 26 TAX ID: \_\_\_\_\_

CONTRACTOR: Fogle's Septic Clean Inc. EMAIL: kevin@foglesinc.com

CONTRACTOR ADDRESS: 580 Obrecht Road, Sykesville, MD 21784 PHONE: 40-795-5670

PROPERTY OWNER: Vincent Camillo EMAIL: \_\_\_\_\_

OWNER ADDRESS: 14331 Bensworth Way, Glenelg, MD 21029 PHONE: \_\_\_\_\_

NUMBER OF BEDROOMS: \_\_\_\_\_ SEPTIC TANK SIZE: \_\_\_\_\_ DRAINFIELD SIZE/TYPE: \_\_\_\_\_

LOCATION:	Remove Observation Pipes (2) from the ends of trenches near the West property line for 14331 Bensworth Way. Remove Observation Pipes from East end of drain field near driveway if directed to do so by homeowner.
NOTES:	Cover exposed gravel with geotextile. Call for inspection by Environmental Sanitarian before covering any work.

ISSUED BY: Robert Bricker ISSUE DATE: \_\_\_\_\_ EXPIRATION DATE: \_\_\_\_\_

- NOTE: CONTRACTOR MUST SCHEDULE AN INSPECTION AND GAIN APPROVAL OF ALL COMPONENTS PRIOR TO COVERING
- NOTE: AN ELECTRICAL PERMIT IS REQUIRED FOR INSTALLATION OF ANY ELECTRICAL COMPONENTS OF THE SYSTEM
- NOTE: MDE RECOMMENDS SEPTIC TANKS, BAT, AND OTHER PRETREATMENT UNITS BE PUMPED AT A FREQUENCY ADEQUATE TO ENSURE THAT SOLIDS ARE NOT DISCHARGED TO THE DISPOSAL AREA

**NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.  
 PERMITTEE RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT.  
 CALL 410-313-1771 FOR INSPECTION OF SEPTIC SYSTEM.**

NOT TO SCALE

**TRENCH/DRAINFIELD DATA**

WIDTH \_\_\_\_\_ INLET \_\_\_\_\_ BOTTOM \_\_\_\_\_  
NUMBER OF TRENCHES \_\_\_\_\_  
TOTAL LENGTH \_\_\_\_\_  
ABSORPTION AREA \_\_\_\_\_  
DISTRIBUTION BOX LEVEL \_\_\_\_\_  
DISTRIBUTION BOX BAFFLE \_\_\_\_\_  
DISTRIBUTION BOX PORT \_\_\_\_\_

**SEPTIC TANK DATA**

SEPTIC TANK 1 LEVEL \_\_\_\_\_  
MANUFACTURER \_\_\_\_\_  
CAPACITY \_\_\_\_\_ GAL  
SEAM LOC \_\_\_\_\_  
TANK LID DEPTH \_\_\_\_\_  
BAFFLES \_\_\_\_\_  
BAFFLE FILTER \_\_\_\_\_  
MANHOLE LOC \_\_\_\_\_  
6" PORT LOC \_\_\_\_\_  
WATERTIGHT TEST \_\_\_\_\_  
SLOTTED \_\_\_\_\_  
DATE ON LID \_\_\_\_\_  
PUMP/SEPTIC TANK LEVEL \_\_\_\_\_  
MANUFACTURER \_\_\_\_\_  
CAPACITY \_\_\_\_\_ GAL  
SEAM LOC \_\_\_\_\_  
TANK LID DEPTH \_\_\_\_\_  
BAFFLES \_\_\_\_\_  
BAFFLE FILTER \_\_\_\_\_  
MANHOLE LOC \_\_\_\_\_  
6" PORT LOC \_\_\_\_\_  
WATERTIGHT TEST \_\_\_\_\_  
SLOTTED \_\_\_\_\_  
DATE ON LID \_\_\_\_\_

Observation pipes covered with ~ 2" of dirt on left side of yard and ~ 6" of dirt on right side of yard.

ROAD NAME

PRE-CONSTRUCTION:

INSTALLATION:

11/9/2015 The end of the trenches near lot 27 had sunk / settled. It appears that trench ends on one side weren't backfilled properly. Trench ends were dug up and new filter cloth was put over the stone. The trenches were backfilled and packed down with the backhoe. Hopefully this will at least lessen any future settling. The observation pipes were cut down

FINAL INSPECTOR

B. Baker

DATE OF APPROVAL

11/9/2015

and covered with ~ 6" of dirt. I had contractor put screws in obs. ports for locating later with metal detector. (BB)



Bureau of Environmental Health  
 8930 Stanford Boulevard, Columbia, MD 21045  
 Main: 410-313-2640 | Fax: 410-313-2648  
 TDD 410-313-2323 | Toll Free 1-866-313-6300  
 www.hchealth.org  
 Facebook: www.facebook.com/hocohealth  
 Twitter: HowardCoHealthDep

Dr. Maura J. Rossman, M.D., Health Officer

**INFORMATION FORM – SEPTIC SYSTEM REPAIR/UPGRADE**

Reason for Request: System

Has the septic tank been pumped within the last month?

- Failing System modification
- System relocation for proposed addition
- System upgrade for proposed addition
- Inadequate treatment zone
- Collapsed septic tank
- Collapsed drywell

Yes Date pumped: \_\_\_\_\_

No

Was a visual inspection of the septic tank and/or drain fields conducted?

Yes Explain observations: \_\_\_\_\_

No

Was a visual inspection of the sewage line conducted?

Yes

Blockage leading to the tank

Yes. Explain: \_\_\_\_\_

No

Blockage leading to the field

Yes. Explain: \_\_\_\_\_

No

Existing system design

- Drywell
- Trench
- Mound
- Unknown
- Other: \_\_\_\_\_

Is discharge surfacing on the ground?

- Yes
- No

No

Additional Comments: remove observation parts

\*For REPAIRS, are the owners proposing, or do they plan to add in the future, any additions or modifications to the property, i.e. pools, living space additions, garages, etc? This information must be disclosed at the time of this application. The Health Department will not be able to accommodate requests in the field for property modifications unrelated to the repair request. Such requests may require an additional fee, testing, and submittal of a Percolation Certification Plan, if the property does not meet current Code and Regulation.

Septic Contractor: Fogle's Septic Clean Contractor's Phone: 410 795 5620  
 Contractor's Address: 500 OBRECHT RD Sykesville MD 21784

Property Address: 14331 Bensworth Way County file: \_\_\_\_\_

Subdivision: \_\_\_\_\_ Lot: \_\_\_\_\_ Year Built: \_\_\_\_\_

Owner's Name: \_\_\_\_\_ Owner's Phone: \_\_\_\_\_

Name of previous owners: \_\_\_\_\_ Existing bedrooms: \_\_\_\_\_

Proposed bedrooms: \_\_\_\_\_

Has this request been previously discussed with a Sanitarian? (Name): \_\_\_\_\_

Public Sewer available/nearby: \_\_\_\_\_

\*A Sanitarian will be in contact within three business days, depending upon the urgency of the situation, to coordinate the scheduling/review of the repair or upgrade.

\*Prior to scheduling inspections, scaled plans should be submitted to clarify the nature of the addition.\*

Print out a copy of Real Property Data via Dept. of Taxation website \_\_\_\_\_ Indexed file found \_\_\_\_\_

If public sewer may be nearby, verify whether sewer is technically "available" through the Bureau of Engineering.

If sewer is available and the property is within the Metropolitan District, connection to sewer is required; if the owner believes reason for exemption exists, the owner should justify the request in writing.

If soil/site conditions are limited and sewer and/or Metro District status is not conducive to connection, the Sanitarian may recommend pursuit of Emergency Sewer Extension or Emergency Metro District Inclusion. The Owner should contact the Bureau of Utilities for details.

No permit is to be issued nor inspection to be scheduled without prior fee collection at the office unless an emergency situation exists. The contractor is to notify office of the emergency situation as soon as possible.

FILE INQUIRY NOTES

14331. Bensworth Way

DATE RESULTS OF REVIEW FOR FILE

10/19/15 Summary of follow-up to 10/16 inspection, following receipt of complaint, i.e. owner (Vincent Decamillo) complains that sinkholes have formed over his septic system, have been filled, then ~~for~~ occurred again.

During 10/16 inspection, I observed an area of disturbance proximate to the ends of the septic system trenches near the West property boundary. The Observation Pipes were not visible above grade. Also, noticed that a small depression occurs proximate to one of the trench ends near the driveway. I suspect that the subsidence is occurring due to soil contact with holes in the Observation Pipes, therefore the ~~Pipes~~ Pipes must be removed.

10/19, I advise the owner to contact his septic system contractor. A Repair Permit will have to be pulled and an inspector will have to be on location when the pipes and trenches are exposed.

\* Permit Fee is waived, per Mike Davis  
R Buckner