

**HOWARD COUNTY HEALTH DEPARTMENT
BUREAU OF ENVIRONMENTAL HEALTH
WELL & SEPTIC PROGRAM
TEL: (410)313-1771 FAX: (410)313-2648**

Information Form for the Installation of the Well Pump, Pitless Adapter, and Supply Piping

NOTE: The installer is responsible for requesting an inspection prior to 9 am on the day of the desired inspection. No work is to be covered until approved by the Health Department. All installations must comply with the National Standard Plumbing Code (NSPC, as amended locally) and COMAR 26.04.04 (MD Well Construction Regulations). Submission of a complete form is required prior to Use and Occupancy approval.

Company Name: FOGLIES Telephone #: 410 443 609 4195
Address: 580 OSBRECHT ROAD
SYKESVILLE, MD 21784

(Must circle one) Licensed Plumber Licensed Well Driller Well CASING EXTENSION
Licensed Well Pump Installer
License # and name of individual responsible for the field installation:
Name (Print): _____ License# _____

***A licensed individual must perform the actual installation. Apprentices must be under the supervision of a licensed journeyman or master plumber, pump installer or well driller. Licenses may be subjected to field verification. Unlicensed individuals may be reported to the appropriate licensing agency.**

Name of Property Owner: NICHOLS, MATT Telephone #: N/A
Subdivision: N/A Lot #: N/A Well Tag #: HO - - - - - JULY 2018
Site Address: 16645 FREDERICK ROAD NO TAG
MT AIRY, MD 21771

<u>Submersible Pump Data</u>	<u>Pitless Adapter</u>	<u>Well Cap and Electric Conduit</u>
Make: <u>N/A</u>	Make: <u>N/A</u>	Two piece watertight cap: <input checked="" type="checkbox"/>
Model #: <u>N/A</u>	Model#: <u>N/A</u>	Screened, vented well cap: <input checked="" type="checkbox"/>
Pump Capacity <u>N/A</u> GPM	Depth: <u>N/A</u> (36" min)	Cap secured to casing: <input checked="" type="checkbox"/>
Well Yield: <u>N/A</u> GPM	NSF/WSC approved: <u>N/A</u>	Conduit min 18" B.G.: <input checked="" type="checkbox"/>
Depth of well encountered at time of pump installation: <u>N/A</u> (feet)		Conduit secured to well cap: <input checked="" type="checkbox"/>
If pump capacity exceeds well yield, a low water cut off switch is required by NSPC 1990 Section 17.8.4		
Torque arrestors, Cable guards, or other acceptable method used- Must circle one		
Safety rope, if used, attached to brass rope adapter or other acceptable method <u>inside of well casing</u>		

<u>Piping to house</u>	<u>House Connection</u>
Type: <u>N/A</u>	PVC sleeve to undisturbed soil at wall penetration: <u>N/A</u>
PSI: <u>N/A</u> (160 psi min)	Length of sleeve(5' minimum from foundation): <u>N/A</u>
Depth of supply line: <u>N/A</u> (36" min)	Sleeve sealed properly: <u>N/A</u>

The water supply line is required to be at least ten feet from the septic tank, pump chamber, sewage piping, distribution box, drainfields, and sewage reserve area. If this cannot be accomplished, contact this office for approval prior to installation.

Signature of company representative responsible for installation _____ date N/A

For Health Department Use Only -- Not to be completed by Installer

Date Insp. Requested: JULY 2018 Date Insp. Approved: JULY 2018 Inspector: [Signature]
 Inspection Data: Pitless adapter watertight & water supply line at least 36" below grade N/A JULY 2018 EXISTING PITLESS
 Two piece cap installed and attached to casing securely
 Elec. conduit extends at least 18" below grade/attached to cap properly
 Safety rope not outside of well cap/casing
 Correct well tag attached properly and casing 8" above finished grade
 Water supply line sleeved adequately at house connection N/A
 Adequate grout observed below pitless adapter N/A JULY 2018 NO TAG, ADEQUATE WELL HEIGHT ABOVE GRADE

JULY 2018
WELL UPGRADED FROM PREVIOUS CONDITION TO MEET PRESENT
WELL CONSTRUCTION STANDARDS. WELL CASING EXTENDED ABOVE
GROUND. FACE WELDED METAL CASING TO METAL CASING.

Fogle's Well Drilling, LLC

P.O. Box 202
Woodbine, Md 21797
443-609-4195
410-795-5670{24hrs}

Invoice

Date	Invoice #
3/17/2017	10396994

PAID

Bill To:

Matt Nichols
14148 Howard Rd
Dayton, Md 21036

Job Location

6645 Frederick Rd
Mt. Airy, Md 21771

<u>Amount of Remittance</u>

P.O. No.	Terms	Project	** 1-1/2 % Late charge due on balances outstanding more than 15 days from date of invoice** (18% per annum)	
	C.O.D.	16645 Frederick Rd		
Qty	Description	Price Each	Serviced	Amount
1	3 hour Yield test	500.00	3/14/2017	500.00
	Well is 315' Deep & Produces 1.5gpm			
1	Misc Fittings to repair piping in pit	25.00	3/14/2017	25.00
	Payment Auth:031226	-525.00	3/31/2017	-525.00
It's been a pleasure working with you!! 24Hr Septic Service{410-795-5670}			Total	\$0.00
			Payments/Credits	\$0.00
			Balance Due	\$0.00

Fogle's Well Pump and Water Treatment, LLC
 580 Obrecht Rd
 Sykesville, MD 21784

Office: 410-795-5670
Fax: 410-795-3432
24 HOUR EMERGENCY SERVICE!!
"LIKE" us on Facebook!!

Invoice

Date	Invoice #
7/3/2018	6282

Job Location

16645 Frederick Rd
 Mt Airy, MD 21771

Bill To

Matt Nichols
16645 Frederick Rd
Mt. Airy, MD 21771

Amount of Remittance:

P.O. No.	Terms	Job	** 1- 1/2% late charge due on balances outstanding more than 30 days from date of invoice** (18% per annum)
	Due on receipt	16645 Frederick Rd	

Quantity	Description	Price Each	Serviced	Amount
	Brought steel well casing up to grade to county code. Removed top rings of concrete blocks from well pit. Chlorinated well. Installed a new 2 piece bug proof well cap. Installed a frost proof hydrant. Techs: Brian, Bryan, Corey, Dave <i>pd. in full via CC ON 7-6-18 [Signature]</i>	1,550.00	7/2/2018	1,550.00

It's been a pleasure working with you!

Total

Payments/Credits \$0.00

Balance Due \$1,550.00