

## FILE INQUIRY NOTES

17520 Hardy Road

| DATE    | RESULTS OF REVIEW FOR FILE  |
|---------|---|
| 7/10/22 | <p>Owner of property leaves voicemail saying that he has two septic systems, one of which includes an orangeberg pipe that discharges to a cesspit. He believes the orangeberg pipe has collapsed and he wants to replace it. Also, he wants to know if he would be able to <del>sell</del> sell his property with the cesspit in use. (No answer when I returned call I sent an email.</p> |
|         | <p>which included Code excerpts for prohibition of cesspits and requirements for permits.</p>   |
| 7/12/22 | <p>During follow-up phone call initiated by owner, I learn that the orangeberg pipe serves one toilet and that the laundry and kitchen discharge by PVC pipe to the cesspit.</p>  |
|         | <p>The issue may be resolved by routing PVC pipe from the toilet to an approved, more modern OSDS. RBuckner</p>   |

WS\_17520

Hardy Road\_

File Inquiry\_

February 2022

R.B.

please Sean & Post