



Bureau of Environmental Health
 8930 Stanford Blvd | Columbia, MD 21045
 410.313.2640 - Voice/Relay
 410.313.2648 - Fax
 1.866.313.6300 - Toll Free

12464 Barnard Way

Maura J. Rossman, M.D., Health Officer

Information Form for the Installation of the Well Pump, Pitless Adapter, and Supply Piping

NOTE: The installer is responsible for requesting an inspection prior to 9 am on the day of the desired inspection. No work is to be covered until approved by the Health Department. All installations must comply with the National Standard Plumbing Code (NSPC, as amended locally) and COMAR 26.04.04 (MD Well Construction Regulations). Submission of a complete form is required prior to Use and Occupancy approval.

Company Name: J+R Plumbing Telephone #: 1443-867-2069
 Address: 502 Carrick Ln
Severn, MD 21144

Must circle one: Licensed Plumber / Licensed Well Driller / Licensed Well Pump Installer
 License # and name of individual responsible for the field installation: Chris Basciano (J+R Plumbing) License # 443-867-2069 MD: #10285
 Name (Print): Chris Basciano (J+R Plumbing) License # 443-867-2069 MD: #10285
 *A licensed individual must perform the actual installation. Apprentices must be under the supervision of a licensed journeyman or master plumber, pump installer or well driller. Licenses may be subjected to field verification. Unlicensed individuals may be reported to the appropriate licensing agency.
 Electrician: A. Dean Electric (matt Perfater) 301-440-3409
 HoCo: 20020010285

Name of Property Owner: Rob + Gail Callahan Telephone #: 410-830-9044
 Subdivision: 12464 Barnard Way Lot #: _____ Well Tag #: HO-21-2715
 Site Address: West Friendship, MD 21794

* cut well line + electric line at house. Relocated further out in yard. Spliced everything back together trench is 40" deep.

Submersible Pump Data	Pitless Adapter	Well Cap and Electric Conduit
Make: _____	Make: _____ +	Two piece watertight cap: _____
Model #: _____	Model #: _____	Screened, vented well cap: _____
Pump Capacity _____	GPM Depth: _____ (36" min)	Cap secured to casing: _____
Well Yield: _____	GPM NSF/WSC approved: _____	Conduit min 18" B.G.: _____
Depth of well encountered at time of pump installation: _____ (feet)		Conduit secured to well cap: _____

If pump capacity exceeds well yield, a low water cut off switch is required by NSPC 1990 Section 17.8.4
 Must circle one: Torque arrestors / Cable guards / Other acceptable method used
 Safety rope, if used, attached to brass rope adapter or other acceptable method inside of well casing

Piping to house	House Connection
Type: _____	PVC sleeve to undisturbed soil at wall penetration: _____
PSI: _____ (160 psi min)	Length of sleeve (5' minimum from foundation): _____
Depth of supply line: _____ (36" min)	Sleeve sealed properly: _____

The water supply line is required to be at least ten feet from the septic tank, pump chamber, sewage piping, distribution box, drainfields, and sewage reserve area. If this cannot be accomplished, contact this office for approval prior to installation.

Signature of company representative responsible for installation: Michelle Engler (Rhine Landscaping) date: 3/25/22
 Rhine Onsite Contact: Mark Kemp 410-984-3410

For Health Department Use Only - Not to be completed by Installer

Date Insp. Requested: <u>3/25/22</u>	Date Insp. Approved: <u>3/28/22</u>	Inspector: <u>(Signature)</u>
Inspection Data: Pitless adapter watertight & water supply line at least 36" below grade		<input checked="" type="checkbox"/> 40"
Two piece cap installed and attached to casing securely		<input checked="" type="checkbox"/>
Elec. conduit extends at least 18" below grade/attached to cap properly		<input checked="" type="checkbox"/> 39"
Safety rope not outside of well cap/casing		<input checked="" type="checkbox"/>
Correct well tag attached properly and casing 8" above finished grade		<input checked="" type="checkbox"/> 17"
Water supply line sleeved adequately at house connection		<input type="checkbox"/> existing
Adequate grout observed below pitless adapter		<input type="checkbox"/> existing

(Revised form 10/24/2018)