

FOUNTAIN VALLEY ANALYTICAL LABORATORY, INC.

1413 Old Taneytown Rd. Westminster, MD (410) 848-1014 (410) 876-4554

REPORT OF ANALYSIS

Laboratory ID #: 155869 Account #: 4035
Reference: Estates at River Hill Lot 12 Client: Trinity Quality Homes, Inc.
Location: 13600 Olivia Way Requested By: Michael Pfau
Highland, MD 20777 Source: Well Water
Date/ Time Collected: 11/18/2022 1200 Site: Pressure Tank
Date/Time Rec'd: 11/18/2022 1348 Treatment: **
Chlorine ppm: Free: ND Total: ND pH: 6.4
Collected By: J. Yeager 0819JY Well #: HO-17-0336

PARAMETERS	RESULTS	UNITS	REFERENCE	METHOD	DATE/TIME/ANALYST
Manganese	0.11	mg/L	0.05*	EPA 200.8	11/29/2022 / 1252 / MBC

NOTES:

- 1 * SMCL = Secondary Maximum Contaminant Level
- 2 Manganese Detection Limit: 0.005 mg/L
- 3 mg/L = milligrams per liter (also, parts per million)
- 4 pH & Chlorine level tested on site
- 5 Sub-contracted to Reference Lab #320
- 6 ND:None Detected
- 7 Visual well check: Sealed, vented cap
- 8 **Sample collected prior to Softener/Sediment Filter

Reason for Test : Use & Occupancy
Building Permit # : B19003295

Date Reported: 12/5/2022

Reviewed By:

Catherine C. Holland