



Bureau of Environmental Health  
 8930 Stanford Blvd | Columbia, MD 21045  
 410.313.2640 - Voice/Relay  
 410.313.2648 - Fax  
 1.866.313.6300 - Toll Free

Maura J. Rossman, M.D., Health Officer

**Information Form for the Installation of the Well Pump, Pitless Adapter, and Supply Piping**

NOTE: The installer is responsible for requesting an inspection prior to 9 am on the day of the desired inspection. No work is to be covered until approved by the Health Department. All installations must comply with the National Standard Plumbing Code (NSPC, as amended locally) and COMAR 26.04.04 (MD Well Construction Regulations). Submission of a complete form is required prior to Use and Occupancy approval.

Company Name: Atlantic Blue, LLC Telephone #: 410-840-2583  
 Address: 1802 Baltimore Blvd  
Wheaton, MD 21157

Must circle one: Licensed Plumber / Licensed Well Driller / Licensed Well Pump Installer

License # and name of individual responsible for the field installation:  
 Name (Print): Mike Sweeney License# 70788

\*A licensed individual must perform the actual installation. Apprentices must be under the supervision of a licensed journeyman or master plumber, pump installer or well driller. Licenses may be subjected to field verification. Unlicensed individuals may be reported to the appropriate licensing agency.

Name of Property Owner: Joe Lazzari Telephone #: 301-708-1522  
 Subdivision: Glenola Manor Lot #: \_\_\_\_\_ Well Tag #: HO-81-1280  
 Site Address: Halls Heritage Hill Ln.  
Ellicott City, MD 21042

**Submersible Pump Data**

Make: Goulds  
 Model #: \_\_\_\_\_  
 Pump Capacity 7  
 Well Yield: 11  
 Depth of well encountered at time of pump installation: 180 (feet)

**Pitless Adapter**

Make: Compbell  
 Model#: \_\_\_\_\_  
 GPM Depth: 42 (36" min)  
 GPM NSF/WSC approved: \_\_\_\_\_

**Well Cap and Electric Conduit**

Two piece watertight cap:   
 Screened, vented well cap:   
 Cap secured to casing:   
 Conduit min 18" B.G.:   
 Conduit secured to well cap:

If pump capacity exceeds well yield, a low water cut off switch is required by NSPC 1990 Section 17.8.4

Must circle one: Torque arrestors  Cable guards  Other acceptable method used

Safety rope, if used, attached to brass rope adapter or other acceptable method inside of well casing N/A

**Piping to house**

Type: poly  
 PSI: 200 (160 psi min)  
 Depth of supply line: 36" (36" min)

**House Connection**

PVC sleeve to undisturbed soil at wall penetration:   
 Length of sleeve (5' minimum from foundation): 20'  
 Sleeve sealed properly:

The water supply line is required to be at least ten feet from the septic tank, pump chamber, sewage piping, distribution box, drainfields, and sewage reserve area. If this cannot be accomplished, contact this office for approval prior to installation.

[Signature] date 8/12/22  
 Signature of company representative responsible for installation

**For Health Department Use Only - Not to be completed by Installer**

Date Insp. Requested: 08/18/2022 Date Insp. Approved: 08/18/2022 Inspector: [Signature]  
 Inspection Data: Pitless adapter watertight & water supply line at least 36" below grade  
 Two piece cap installed and attached to casing securely  
 Elec. conduit extends at least 18" below grade/attached to cap properly  
 Safety rope not outside of well cap/casing  
 Correct well tag attached properly and casing 8" above finished grade  
 Water supply line sleeved adequately at house connection  
 Adequate grout observed below pitless adapter

[Signature]  
 TIE IN FROM HOUSE  
 TO GAR/BARN  
 CROSSING 2x  
 GAS PIPELINE  
 AND 1x DEAD GAS  
 PIPE LINE.

(Revised form 10/24/2018)