

## Williams, Jeffrey

---

**From:** Williams, Jeffrey  
**Sent:** Friday, November 6, 2020 1:51 PM  
**To:** Paul Sill  
**Subject:** RE: Streaker SDP Health comment SDP-20-049

Hi Paul. This property is served by onsite water and sewer, so Health should sign all pages except notes pages  
Jeff

**From:** Paul Sill <paul@sillengineering.com>  
**Sent:** Thursday, November 5, 2020 11:26 AM  
**To:** Williams, Jeffrey <jewilliams@howardcountymd.gov>  
**Subject:** RE: Streaker SDP Health comment SDP-20-049

[Note: This email originated from outside of the organization. Please only click on links or attachments if you know the sender.]

Checking in on this question.

**From:** Paul Sill  
**Sent:** Wednesday, October 28, 2020 12:36 PM  
**To:** Williams, Jeffrey <jewilliams@howardcountymd.gov>  
**Subject:** FW: Streaker SDP Health comment SDP-20-049

Hey Jeff,

See the attached comment on this SDP. We've added the signature blocks, but I'm curious: why does Health need to sign on this one?

Thanks,  
Paul

**From:** Mike O'Brien <Mike@sillengineering.com>  
**Sent:** Wednesday, October 28, 2020 10:08 AM  
**To:** Paul Sill <paul@sillengineering.com>  
**Cc:** Lori Aronow <lori@sillengineering.com>  
**Subject:** Streaker SDP Health comment

See attached

Mike O'Brien  
Civil Designer  
MDE Responsible Personnel Certification #RPC006981

**Sill Engineering Group, LLC**  
16005 Frederick Road, 2<sup>nd</sup> Floor  
Woodbine, MD 21797  
Office: 443.325.5076 ext 103  
Fax: 410.696.2022

**SDP-20-049**

<b>File Name</b>	<b>Markup Name</b>	<b>Markup Text</b>	<b>Markup Date</b>	<b>Created by</b>
C01_Cover_Sheet_18-053.pdf	SEG replies - Health		10/26/2020	Michael O'Brien
C01_Cover_Sheet_18-053.pdf	SEG replies - Health	add note stating that all sewage disposal areas, disposal systems, and wells on the property must meet all applicable codes prior to Health Dept approval of any building permits on the site.	10/26/2020	Michael O'Brien
C01_Cover_Sheet_18-053.pdf	SEG replies - Health	Health Department will perform a site visit to confirm that there are no public health nuisance conditions on the site such as a failing septic system prior to signature of the Site Development Plan. Any observed nuisances must be abated prior to Health signature.	10/26/2020	Michael O'Brien
C01_Cover_Sheet_18-053.pdf	SEG replies - Health	Add a note or chart indicating the number of employees on site as part of the operation	10/26/2020	Michael O'Brien
C01_Cover_Sheet_18-053.pdf	SEG replies - Health		10/26/2020	Michael O'Brien
C01_Cover_Sheet_18-053.pdf	SEG replies - Health		10/26/2020	Michael O'Brien
C01_Cover_Sheet_18-053.pdf	SEG replies - Health		10/26/2020	Michael O'Brien
C01_Cover_Sheet_18-053.pdf	SEG replies - Health		10/26/2020	Michael O'Brien
C01_Cover_Sheet_18-053.pdf	Jeff Williams		06/01/2020	Jeffrey Williams
C01_Cover_Sheet_18-053.pdf	Jeff Williams	add note stating that all sewage disposal areas, disposal systems, and wells on the property must meet all applicable codes prior to Health Dept approval of any building permits on the site.	06/01/2020	Jeffrey Williams

C01_Cover_Sheet_18-053.pdf	Jeff Williams	Health Department will perform a site visit to confirm that there are no public health nuisance conditions on the site such as a failing septic system prior to signature of the Site Development Plan. Any observed nuisances must be abated prior to Health signature.	06/01/2020	Jeffrey Williams
C01_Cover_Sheet_18-053.pdf	Jeff Williams	Add a note or chart indicating the number of employees on site as part of the operation	06/01/2020	Jeffrey Williams