



MAJ
6/20/05
X MUST show
3 Proposed
wells 50' apart
or well box 1,500ft²

TEST NO	DEPTH	PRE WET		TEST - 1" DROP		TIME
		START	STOP	START	STOP	
①	4'	11:03	11:04	11:04	11:05	1min
	10'	LOG M - SANDY				
②	3 1/2'	11:11	11:14	11:14	11:24	10min
	12 1/2'	LOG M - SANDY				
③	3'	11:06	11:07	11:07	11:08	1min
	12 1/2'	LOG M - SANDY				
④	4'	11:09	11:12	11:12	11:16	4min
	10'	LOG M SANDY				

X Proposed well
sites MAY NOT
be @ lower
elevation compared
to surrounding
septic areas

PLAN NOT
ACCEPTABLE
KN

5/11/05 Tests were taken - test on gas
[• indicates stake] N. road
C.B.D. (Name as =)
ALSO PRESENT: CANYON OF HATFIELD

Owner/Developer
Dr. Bradley S. Daines
3133 Daisy Road
Woodbine, MD 21797
Tel. 410-489-0383

No.	Date	Revisions / Submissions

Drawings based on Border Survey 2004 by
KCE Engineering Inc.

S 2d33m46s W