



Bureau of Environmental Health
8930 Stanford Blvd | Columbia, MD 21045
410.313.2640 - Voice/Relay
410.313.2648 - Fax
1.866.313.6300 - Toll Free

Maura J. Rossman, M.D., Health Officer

APPLICATION
FOR PERCOLATION TESTING AND SITE EVALUATION

PROPERTY LOCATION

SUBDIVISION/PROPERTY NAME Hopkins Meade
PROPERTY ADDRESS 7416 Cherry Tree Dr Clarksville 21029
STREET TOWN ZIP
TAX ACCOUNT # 05-349591 TAX MAP 41 GRID 14 PARCEL 357 LOT NO. 3 PROPOSED LOT SIZE (ACRES)
ZONING CATEGORY TIER

PROPERTY OWNER(S)

Seth Gursek
DAYTIME PHONE 443-742-4199 CELL EMAIL qbasic92@hotmail.com
MAILING ADDRESS 7416 Cherry Tree Dr Clarksville, MD 21029
STREET CITY, STATE ZIP

APPLICANT

Fogle's Septic Clean, Inc. RELATIONSHIP TO OWNER: Septic Contractor
DAYTIME PHONE 410-795-5670 CELL EMAIL john@foglesinc.com
MAILING ADDRESS 580 Obrecht Rd Sykesville, MD 21784
STREET CITY, STATE ZIP

I HEREBY APPLY FOR THE NECESSARY TESTING/EVALUATION PRIOR TO ISSUANCE OF SEWAGE DISPOSAL SYSTEM PERMIT(S):

PROPERTY:

- SUBDIVISION: NUMBER OF LOTS INCLUDING RESIDUE:
SUBDIVISION CLASSIFICATION (PER DEPT. OF PLANNING AND ZONING) MAJOR MINOR
CONSTRUCT NEW OSDS ON UNDEVELOPED LOT
REPAIR OR REPLACE FAILING OSDS
UPGRADE EXISTING OSDS

BUILDING:

- RESIDENTIAL WITH 5 EXISTING OR PROPOSED BEDROOMS IN THE COMPLETED STRUCTURE
COMMERCIAL (PROVIDE DETAIL OF TYPE OF USE AND NUMBERS OF EMPLOYEES/CUSTOMERS ON ACCOMPANYING PLAN)

IS THE PROPERTY WITHIN 2500 FEET OF ANY RESERVOIR?

- YES
NO

AS APPLICANT, I UNDERSTAND THE FOLLOWING:

- THIS APPLICATION IS VALID FOR TWO(2) YEARS FROM DATE OF FEE PAYMENT AND APPROVAL IS BASED UPON HEALTH OFFICER SIGNATURE OF A PERC CERTIFICATION PLAN PRIOR TO EXPIRATION OF THIS PERMIT.
THE APPLICATION FEE IS NON-REFUNDABLE
THIS APPLICATION MUST BE ACCOMPANIED BY ALL APPLICABLE FEES AND A SUITABLE SITE PLAN IN ORDER TO BE PROCESSED
THIS IS A PUBLIC DOCUMENT

I declare and affirm that to the best of my knowledge, the information contained herein is correct. I declare that I am the owner of the property or duly authorized to make this application on behalf of the owner. I agree to comply with all applicable state and county regulations.

By signature of this application, I hereby grant Howard County Health Department officials the right to enter onto the property for the purpose of inspecting the property as directly related to the requested permit/service.

[Handwritten Signature]

6/18/2024

SIGNATURE OF APPLICANT

DATE

RECEIPT

Howard County, MD
HOWARD COUNTY HEALTH DEPARTMENT
ASCEND ONE BUILDING
Columbia, MD 21045
8930 STANFORD BLVD

Application: WS-PT-24-01708
Application Type: EnvHealth/Well and Septic/Percolation Test/Application
Address: 7416 CHERRY TREE DR, Clarksville, 21029

Receipt No.	Ref Number	Amount Paid	Payment Date	Cashier ID	Received	Comments
10009	80420	\$265.00	06/18/2024	SMARTIN		

Owner Info.:
MESTER SANDOR S
7416 CHERRY TREE DR
CLARKSVILLE, MD 21029

Work Description:

RECEIPT


Howard County, MD
HOWARD COUNTY HEALTH DEPARTMENT
ASCEND ONE BUILDING
Columbia, MD 21045
8930 STANFORD BLVD

Application: WS-SP-APP-24-00109
Application Type: EnvHealth/Well and Septic/Sewage Disposal System/Application
Address: 7416 CHERRY TREE DR, Clarksville, 21029

Receipt No.	10008					
Payment Method	Ref Number	Amount Paid	Payment Date	Cashier ID	Received	Comments
Check	80420	\$265.00	06/18/2024	SMARTIN		

Owner Info.: MESTER SANDOR S
7416 CHERRY TREE DR
CLARKSVILLE, MD 21029

Work Description:



(A)
 Dr/Y CL
 WK COSBK,
 Friable CW
 15% coarse frags
 2'
 wk Dr/Rd L
 WK F SBK
 Friable CW
 many mica
 15% chert
 5'
 B-|Rd/Y SCL
 WK F SBK
 Friable, wk
 iron inclusions
 7'
 li-B-Y/R SL
 WK Co PL
 Frab
 15% schist
 chert
 10% spr
 15'

DATE	TEST #	DEPTH	START	BREAK 1" DROP	STOP 2" DROP	TIME OF 2ND INCH	P/F/H
6/27/2021	(A)	5' / 15'	00:24	00:31	00:46	15	P
		120' drilled @ 15'				~5 min	P
		7' 6"	00:52	00:54	00:57	3	P

REMARKS Ex. dry full full. Poorly dy

SANITARIAN K. Wolf BACKHOE reley 6.1m OTHERS owner

TEST HOLES USED IN SDA 1 AVG. PERC TIME 9 SQ. FT/BR 1.2 gal/ft

TRENCH WIDTH 2' INLET DEPTH 4' MAX. BOT DEPTH 10 EFFECTIVE SW 5.5' - 10(.33)

5 BR. $\frac{2750}{0.8} = 937.5 \div 2 = 469 (.33) = 155$ (2 x 80')





Bureau of Environmental Health
 8930 Stanford Blvd | Columbia, MD 21045
 410.313.2640 - Voice/Relay
 410.313.2648 - Fax
 1.866.313.6300 - Toll Free

Maura J. Rossman, M.D., Health Officer

INFORMATION FORM - SEPTIC SYSTEM REPAIR/UPGRADE

Reason for Request:

- Failing System
- System relocation for proposed addition
- System upgrade for proposed addition
- Inadequate treatment zone
- Collapsed septic tank
- Collapsed drywell

Has the septic tank been pumped within the last month?

Yes Date pumped: _____
 No

Was a visual inspection of the septic tank and/or drain fields conducted?

Yes Explain observation: Drywell is hydraulically loaded. Excavated trench off drywell, trench is also hydraulically loaded.
 No

Existing system design

- Drywell
- Trench
- Mound
- Unknown
- Other: _____

Was a visual inspection of the sewage line conducted?

Yes
 No

Blockage Leading to the field

Yes Explain _____
 No

Is discharge surfacing on the ground?

Yes
 No

Additional Comments:

*For REPAIRS, are the owners proposing, or do they plan to add in the future any additions or modifications to the property, i.e. pools, living space additions, garages, etc? This information must be disclosed at the time of this application. The Health Department will not be able to accommodate requests in the field for property modifications unrelated to the repair request. Such requests may require an additional fee, testing, and submittal of a Percolation Certification Plan, if the property does not meet current Code and Regulations.

Septic Contractor: Fogle's Septic Clean, Inc. Contractor's Phone: 410-795-5670

Contractor's Address: 580 Obrecht Rd Sykesville, MD 21784

Property Address: 7416 Cherry Tree Dr County File: 05-349591

Subdivision: Hopkins Meade Lot: 3 Year Built: 1973

Owner's Name: Seth Gursek Existing bedrooms: 5

Name of previous owners: Sandor Mester Existing bedrooms: _____

John Fato Proposed bedrooms: _____

*A Sanitarian will be in contact within three business days, depending upon the urgency of the situation, to coordinate the scheduling/review of the repair or upgrade.

Prior to scheduling inspections, scaled plans should be submitted to clarify the nature of the addition.

Print out a copy of Real Property Data via Dept. of Taxation website _____ Indexed file found _____

If soil/site conditions are limited and sewer and/or Metro District status is not conducive to connection, the Sanitarian may recommend pursuit of Emergency Sewer Extension or Emergency Metro District Inclusion. The Owner should contact the Bureau of Utilities for details.

No permit is to be issued nor inspection to be scheduled without prior fee collection at the office unless an emergency exists.

The contractor is to notify the office of the emergency as soon as possible.

2/2020