

Record Detail * (This section is required.)

Permit Type	Permit Number	Opened Date
Building/Residential/Misc/Tanks	[REDACTED]	01/31/2025
Description of Work		
SFD//INSTALL (1) 500 GAL UNDERGROUND PROPANE TANK		

[check spelling](#)

Address * (This section is required.)

Search Reset Clear Get Parcel & Owner

Street #	Street Name	Street Type	
778	CHESSIE CROSSING	WAY	
Unit Type	Unit #	X Coordinate	Y Coordinate
--Select--		-77.05526	39.35585
City	State	Zip Code	Primary
WOODBINE	MD	21797	Yes

Approved 2/7/25
[Signature]

Parcel * (This section is required.)

Search Reset Clear Get Address & Owner

GIS ID *	Parcel	Parcel Area	Land Value	Improved Value	Exemption Value	Plan Area
830554	4	3	95000	838800	0	RURAL

Legal Description

LOT 28 3.0000 A []778 CHESSIE CROSSING WAY[]CHESSIE CROSIING S 2

[check spelling](#)

Block	Census Tract	Council Dist	Inspection Dist	Supervisor Dist	Map #	DAP Zone
[REDACTED]	604001	5				
Plan Area	State Tax Id	Subdivision Name				
	1404353668	CHESSIE CROSSING				
Section	Area	Tax Map				
		3				
Grid	Zoning District	ADC Map				
3-19	RC-DEO	4692-B4				
SDP No.	Final Plan No.	WP File No.				
Record Plat No.	WS Contract No.	FDP No.	Primary			
10463			Yes			
Owner Occupied	Year Built	Historic District				
<input type="radio"/> Yes <input type="radio"/> No	1999	<input type="radio"/> Yes <input checked="" type="radio"/> No				
Historic District Registry No.	Stat Area	Flood Plain				
	4-02	<input type="radio"/> Yes <input checked="" type="radio"/> No				
Building No						

Owner * (This section is required.)

Search Reset Clear

Name *

BINDR

Address Line 1

778 CHESSIE CROSSING WAY

Address Line 2

Address Line 3

Mail City
 WOODBINE
Mail State
 MD
Mail Zip Code
 21797
Phone
 443-610-7514
Primary
 Yes
E-mail

Cell Number **Fax Number**

Professionals (This section is not required.)

License # *	Business Name		
20100102776	N/A		
License Type *	First Name	Middle Name	Last Name
Propane Gs	ROBERT	FRANCIS	HINKLEMAN
Primary	Address Line 1		
Yes	5260 WESTVIEW DR., STE. 200		
	Address Line 2		
	City	State	ZIP Code
	FREDERICK	MD	21703
	Phone 1	Phone 2	Fax
	410-652-0050	855-965-5577	
	E-mail		
	RHINKLEMAN@ [REDACTED] .COM		

Applicant (This section is not required.)

Search As Owner As Lic. Prof As Contact

Type *	First Name	MI	Last Name
Applicant	MICHELLE		CLANCY
Relationship	Full Name		
Applicant	MICHELLE CLANCY		
Primary	Organization Name		
Yes	APPLIED & APPROVED PERMITS LLC		
	Street Address		
	P.O. BOX 310		
	Address Line 2		
	City	State	Zip Code
	PERRY HALL	MD	21128
	Phone	Cell	Fax
	443-340-1229		
	E-mail *		
	MICHELLE@APPLIEDANDAPPROVED.COM		

Addtl Info

Est Construction Cost *	Housing Units *	Number of Buildings *	Public Owned
750	0	0	No
Construction Type			
329 - Structures Other Than Buildings (Retaining Walls/Tents)			

TANK INFORMATION

RESIDENTIAL TANK INFORMATION

Capital Project-No Fee *	Capital Project Number	Fee Exempt *	Roadside Tree Project Permit *	Roadside Tree Permit #
<input type="radio"/> Yes <input checked="" type="radio"/> No	[Text]	<input type="radio"/> Yes <input checked="" type="radio"/> No	<input type="radio"/> Yes <input checked="" type="radio"/> No	[Text]
Existing Use *	Number of Tanks Installed *	Number of Tanks Removed *		
SFD	1 (Number)	0 (Number)		

CTA
Surveyors, LLC

4-43,039,2884



MD 21797

BOOK DATE: 6/18/2024

SURVEYORS CERTIFICATE
 INFORMATION SHOWN HEREON
 HAS BEEN BASED UPON THE
 RESULTS OF A FIELD INSPECTION
 ACCORDANT TO THE DEED OR PLAT
 RECORD. THIS PLAT WAS
 PREPARED UNDER MY DIRECT
 SUPERVISION IN ACCORDANCE
 WITH C.O.M.A.R. SECTION 09.13.06.06
 NOW ADOPTED BY THE
 BOARD OF LAND SURVEYORS
 OF MARYLAND. THE PRESENCE
 OF THIS INFORMATION IS OF
 NO BENEFIT TO A CONSUMER
 UNLESS IN SO FAR AS IT IS
 REQUIRED BY A LENDER OR A
 TITLE COMPANY IN CONNECTION
 WITH A FINANCED TRANSACTION
 OR RECORDING OR REFUNDING
 THE TRANSACTION DEPICTED
 HEREON.

2406.2155
 LOCATION DRAWING
 HOWARD COUNTY

Scale
 1-100



P.33
 LIBER 7558
 FOLIO 599

WOODBINE MORGAN ROAD
 (50' R/W)
 S 64°11'34" E
 110.88' (P)

N 51°44'21" E
 127.18' (P)

60' B.R.L.

LOT 28
 130,880 S.F.
 3 Ac


SEPTIC AREA

N 13°06'38" W
 567.16' (P)

S 15°03'55" E
 529.57' (P)

LOT 27

INSTALLING 100 GALLON
 1/4 TANK AND CONNECTING
 TO POOL HEATER



N 71°23'17" W

A=68.24' (P)
 65.00'



~~W/ ELEM~~
~~PROPERTY LINE~~
~~DRIVE WAY~~

plan matches archive
 files
 Approved for LP tank
 B25000420
 [Signature] 2/7/25

PLEASE NOTE
 Per Maryland State Code, Sec.
 09.13.06.06, this House Location
 Drawing is not to be relied upon to
 determine property boundaries or the
 establishment or location of existing or
 future improvements.



ABOVEGROUND/UNDERGROUND PROPANE STORAGE TANKS 120 - 1000 Gallons



PRESSURE VESSEL CODES & REGISTRATION

- Designed and constructed in accordance with the ASME Section VIII, Division 1 Code
- Registered with the National Board of Boiler & Pressure Vessels Inspectors
- Complies with NFPA 58
- Conforms to specifications set forth by the Railroad Commission of Texas

VESSEL FEATURES

- Tanks fully fitted with RegO valves and Rochester liquid level gauges
- Dual service options for aboveground or underground applications
- Product supplied with steel dome (custom colors available upon request) or plastic AG/UG shroud, specify at time of order
- Container pressure rated at 250 PSI @ 400°F
- Vacuum purged
- Stainless steel data plate
- Anode bolt connection located under the dome
- #54 liquid level outage valve orifice

PROCESS CONTROL

All welded products are x-rayed and pressure tested @ 325 PSI per ASME Sec VIII, Div I requirements, followed by rigorous leak test inspections, both pre and post valving

STORAGE & DISTRIBUTION

Contact Propane Education & Research Council for additional resources and information at propane.com

PAINT SPECIFICATIONS

At the time of order, customer must specify intended application thus determining paint applied at the time of manufacturing

Aboveground tank applications:

- Painted Sky White with super durable TGIC polyester powder paint for maximum rust protection
- Custom colors available upon request
- If an aboveground painted tank is intended for underground use, tank must be field painted for such application

Underground tank applications:

- Painted gray with a "ready to bury", durable epoxy powder paint for underground applications
- Product used underground may require additional protective coating and cathodic protections, contact your federal, state or local authorities for specifications

Made With Pride



Made In the U.S.A.



ABOVEGROUND/UNDERGROUND PROPANE STORAGE TANKS 120 - 1000 Gallons

ABOVEGROUND/UNDERGROUND VESSEL DIMENSIONS & SPECIFICATIONS (All Vessel Dimensions are Approximate)

Part Number	Description	Water Capacity Gal/l	Outside Diameter In/mm	Head Type	Overall Length In/mm	Overall Height In/mm	Leg Width In/mm	Leg Spacing In/mm	Weight Lbs/kg	Quantity	
										Full Load	Per Stack
68280.6	120 Gallon AG/UG Storage Tank, Gray	120	24"	Ellip	5' 8"	3' 1 3/16"	10 1/8"	3' 0"	312	96	12
		454.2	609.6		1727.2	944.5	257.2	914.4	141.5		
68281.6	250 Gallon AG/UG Storage Tank, Gray	250	30"	Hemi	7' 10"	3' 6 15/16"	12 3/4"	3' 6"	462	54	9
		946.3	762		2387.6	1090.6	323.9	1066.8	209.5		
68282.6	320 Gallon AG/UG Storage Tank, Gray	320	30"	Hemi	9' 7"	3' 6 15/16"	12 3/4"	4' 0 1/4"	567	45	9
		1211.3	762		2921	1090.6	323.9	1225.6	257.2		
68283.26**	500 Gallon AG/UG Storage Tank, Gray	500	41"	Hemi	8' 8 1/2"	4' 4"	16 1/4"	3' 6"	987	30	5
		1892.7	1041.4		2654.3	1320.8	412.8	1066.8	447.7		
68284.26**	1000 Gallon AG/UG Storage Tank, Gray	1000	41"	Hemi	15' 11"	4' 5 3/4"	16 1/4"	9' 0"	1739	15	5
		3785.4	1041.4		4851.4	1365.3	412.8	2743.2	788.8		

† Federal, state or local regulations may contain specific applicable requirements for protective coatings and cathodic protection. The purchaser and installer are responsible for compliance with such federal, state, local and NFPA industry regulations, including, but not limited to, proper purging prior to putting into service. Cathodic protection is required. Coating (s) must be continuous, uninterrupted and must comply with local, state or national codes or regulations.

* Drain **No Drain

