



5/25/89

WPF 5/18/89 AM

5/18/89 Partial  
see below  
ANN already C.B.S.

HOWARD COUNTY HEALTH DEPARTMENT  
Bureau of Environmental Health  
3525-H Ellicott Mills Drive  
Ellicott City, MD 21043  
461-9933

APPLICATION FOR PITLESS ADAPTER, WELL PUMP AND PRESSURE TANK INSTALLATION

New Installation   
Replacement

Receipt # 44135  
Date 4.27.89

Name of Installer ACKERT+SOOS, INC

Telephone 301-897-0700

License Number 11637

Certified Well Pump Installer  Well Driller  Registered Plumber

Name of Property Owner C. Dwight + Shirley Fletcher

Telephone 301-334-4000

Subdivision BURKSKIN WOODS Lot # 330

Well Tag # 170-91-162

Site Address 4205 BUCKSKIN LAKE DRIVE

WELL ABANDONED - COL. AP 500

NEW WELL - HO-58-1149 ← SEE OTHER SIDE

- Pump
- Type
    - Deep well jet
    - Shallow well jet
    - Submersible
  - Make JALUZZI
  - Model # SBS479-S2
  - Capacity 7 GPM
  - Pump exceeds well capacity Yes  No
  - If Yes, is low pressure cutoff switch installed? Yes  No
  - What methods are used to protect the pump and electrical wiring from vibrations? Torque arrestors  Cable guards  Other

- Motor
- Horsepower 1/2
  - RPM 1750
  - Voltage
    - 110
    - 220

- Pitless Adapter
- Make DICKISON
  - Model # JPS11P
  - Depth 170'

- Tank
- Capacity 82 GAL
  - Pressure relief valve?

- Piping
- Type Poly
  - Size 4"
  - NSF and/or BOCA Code approved
  - Depth of supply line 42"

- Well data
- Depth 170 ft.
  - Yield 10 GPM
  - Static water level 40 ft.
  - Will water supply be disinfected by installer? NO

I understand that it is my responsibility to notify the Howard County Health Department when the installation is ready for inspection (otherwise this permit is null and void).

All information given above is true to the best of my knowledge.

Signature of Applicant: Bradley L. Acton

Date: 4.28.89

Note: A sticker indicating approval/status of the installation will be placed on the well casing at the time of the inspection.

HD-215

only trench dug } 5/18/89 Partial pitless adapter being not in A.M. and no line is in C.B.S.

5/25/89 - OK TO COVER OUT SIDE WORK PRESSURE TANK NOT YET INSTALLED



\*\*\*\*\*  
 WATER WELL ABANDONMENT-SEALING REPORT FORM  
 \*\*\*\*\*

45566

SUBMIT COPIES OF COMPLETED FORM TO:

- \* COUNTY ENVIRONMENT AGENCY (contact MDE, WMA if address needed)
- \* WELL OWNER
- \* MDE, WATER MANAGEMENT ADMINISTRATION, WELL PROGRAM

DATE WELL ABANDONED: 10/13/99 (month/day/year)

\* PERMIT NUMBER OF ABANDONED WELL (if any)

710 - 81 - 1621

\* PERMIT NUMBER OF REPLACEMENT WELL

710 - 94 - 2459

\* PERSON ABANDONING WELL: Joseph L. Mayne

WELL DRILLERS LICENSE NUMBER: 024

CIRCLE: MWD/MSD/MGD

\* OWNER'S NAME: Dwight F. Fletcher

\* WELL LOCATION:

COUNTY: Howard

NEAREST TOWN: Dayton

TAX MAP \_\_\_\_\_ BLOCK \_\_\_\_\_ PARCEL \_\_\_\_\_

SUBDIVISION: Buckskin Woods

SECTION: \_\_\_\_\_ LOT: 38

NEAREST ROAD: 4205 Buckskin Lake Dr.

	+
000	
000	

SHOW WELL LOCATION  
 BY X WITHIN BOX

MARYLAND GRID COORDINATES

BOX NUMBER  
 E 500  
 N 510

\* TYPE OF WELL BEING ABANDONED:

- DRILLED
- BORED/AUGURED
- OTHER (specify) \_\_\_\_\_
- JETTED
- HAND DUG

\* USE CODE:

- DOMESTIC
- IRRIGATION
- TEST/OBSERVATION
- MUNICIPAL/PUBLIC
- INDUSTRIAL

\* TYPE OF CASING:

- STEEL
- CONCRETE
- PLASTIC
- OTHER (specify) \_\_\_\_\_

\* SIZE OF CASING: 6 3/8 INCHES IN DIAMETER

\* DEPTH OF WELL: 40 FEET DEEP

\* WAS ANY CASING REMOVED?  YES  NO  
 if yes, length removed, in feet: 2

\* WAS CASING RIPPED OR PERFORATED?  YES  NO

LOG OF SEALING MATERIAL

MATERIAL	FEET	
	FROM	TO
<u>Cement</u>	<u>0</u>	<u>40</u>

SIGNATURE-MASTER WELL DRILLER OR SUPERVISING SANITARIAN: Joseph L. Mayne LICENSE #: 024 CIRCLE ONE: MWD/MSD/MGD DATE: 10/27/99