

6-6-88
Ray

APPLICATION FOR PITLESS ADAPTER, WELL PUMP AND PRESSURE TANK INSTALLATION

Howard County Health Department
Bureau of Environmental Health
3525-H Ellicott Mills Drive
Court House Square
Ellicott City, Md. 21043
461-9933

6/6/88
partial (guttered)
WPI OK'd
sticker attached
(P)

New Installation
Replacement

Receipt # 411689
Date 2-28-88

Name of Installer Frederick Plumbing + Heating - Telephone 301-663-4589

License number _____
Certified Well Pump Installer _____ Well Driller _____ Registered Plumber _____

Name of Property Owner Fred + Barb NUSS Telephone 301-622-9197
Subdivision Florence Farms Lot # 7 Well tag # HO-81-26624
Site Address 3132 CABIN RUN

Pump

- Type
 - Deep well jet _____
 - Shallow well jet _____
 - Submersible
- Make Couder
- Model # SEJ07H12
- Capacity 5 GPM
- Pump exceeds well capacity Yes No _____

Motor

- Horsepower 1/2
- RPM _____
- Voltage _____
 - 110 _____
 - 220

Pitless Adapter

- Make Martinson
- Model # A70X
- Depth 118"

pitless in ~44" below
grade OK
pump & power lines in
& OK
(no ground
plastic
casing)

Tank

- Capacity 40 gal
- Pressure relief valve?

Piping

- Type 160 16 poly
- Size 1" black
- NSF and/or BOCA Code approved
- Depth of supply line 48"

Well data

- Depth _____ ft.
- Yield _____ GPM
- Static water level _____ ft.
- Will water supply be disinfected by installer? _____

I understand that it is my responsibility to notify the Howard County Health Department when the installation is ready for inspection (otherwise this permit is null and void).

All information given above is true to the best of my knowledge.

Signature of Applicant: James S. Guff

Date: 2-29-88

Note: A sticker indicating approval/status of the installation will be placed on the well casing at the time of the inspection.