

RECORDED 1956

~~PRELIMINARY~~

APPLICATION

A 28106

LIBER 145
FOLIO 201

P _____

9:30 A.M.

SEWAGE DISPOSAL TESTING

STATE OF MARYLAND - DEPARTMENT OF HEALTH AND MENTAL HYGIENE

DISTRICT 4th

HOWARD COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SERVICES
P O. BOX 476, ELLICOTT CITY, MARYLAND 21043
TELEPHONE: 465-5000, EXT. 356

DATE 5/29/78

DITCH 3 BR - 158 FT LONG 6 FT DEEP 3 FT STONE
4 BR 100 FT LONG 6 FT DEEP 3 FT STONE
START THE DITCH 25 FT FROM THE FRONT
LOT LINE AND 20 FT FROM THE RIGHT
SIDE OF THE LOT AS SEEN FROM THE FRONT
TO THE COUNTY HEALTH OFFICER THE LOT FROM CARRS MILL RD
ELLICOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TEST IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM. DONALD HILL OWNER LIVES AT HENRITTON HOSPITAL
PROPERTY OWNER Louis E. & Betty A. Britton BUYER

ADDRESS 15407 Frederick Road, Woodbine, Md. 21797 PHONE 489-4359

PROPERTY LOCATION RUN THE DITCH TOWARD THE LEFT SIDE OF THE LOT
W-465-9487

SUBDIVISION ALONG LEVEL GROUND LOT NO. Parcel 131

ROAD AND DESCRIPTION Carr's Mill Road - 2nd or 3rd lot down from Route 144; west side
TWO DITCHES NEEDED. NO DITCH

OVER 100 FT IN LENGTH
SIZE OF LOT 1 acre m/l TYPE BLDG. 3 or 4 bedrooms

CONNECT 5 DITCH WITH DISTRIBUTION BOX
IF NOT SINGLE RESIDENCE DESCRIBE

LIBER 145 Folio 201 DITCHES AT LEAST 20 FT APART
THE SYSTEM INSTALLED UNDER THIS APPLICATION IS ACCEPTABLE ONLY UNTIL PUBLIC FACILITIES BECOME AVAILABLE.

SIGNATURE OF APPLICANT /s/ Jack Boender

APPROVED BY Raymond Hodges FOR DITCH DATE 2/7/78
(KIND OF SYSTEM)

REJECTED BY _____ FOR _____ DATE _____
(KIND OF SYSTEM)

HOLD PENDING FURTHER TESTS _____ DATE _____

REASONS FOR REJECTION OR HOLDING 6/16/78 - ROCK HOLD FOR REVIEW
2/7/78 FINAL PLAT SIGNED DM HOLD
LOT FOR REVIEW & DECIDED DITCH OK

THIS IS NOT A PERMIT

49

500
25.0

INDICATE NORTH - NAME ADJOINING ROADWAY AS BASE LINE

DATE	TEST NO.	DEPTH	PRE-WET		TEST - 1" DROP		TIME	
			START	STOP	START	STOP		
6/16/78	15	3 1/2	1036	1108	Little Peck	FAILED		
	1D	9	SAND CLAY ROCK PIECES ROCK BOTTOM					
	2S	3'	1121	1128	1128	1134	6	
	2M	7'	1138	1143	1143	1157	14	
	2D	10	ROCK BOTTOM DRY					
	3D	12	1207	1212	1212	1235	23	
	3M	6 1/2	1207	1210	1210	1216	6	
	3S	4'	1209	1216	1216	1226	10	
	4S	4	1238	1242	1242	1247	5	
6/16/78	4D	11	TOP 3 FT CLAY MTD BY SAND ROCK BOTTOM DRY					

X=11min
INLET 3-
BOTTOM 6-

REMARKS: 6/13/76 MRS BRITTON SAID BOENDER SAID ONLY TWO HOLES NEEDED (LOT ON RECORD BEFORE 1972)
TYPE OF SOIL: RECORDED 1958 OBSERVED DEEP (RD)

TESTED BY: B HODGES
ALSO PRESENT: BETTY BRITTON, LOUIS BRITTON, BRITTINGHAM CO