

C 1 4022
SEQUENCE NO. (DWR USE ONLY)
1 2 3 (SEQ. NO.)
(THIS NUMBER IS TO BE PUNCHED IN COLS 2-3 ON ALL CARDS)

STATE OF MARYLAND
WATER RESOURCES ADMINISTRATION
TAWES STATE OFFICE BLDG., ANNAPOLIS, MD. 21401
WELL COMPLETION REPORT

THIS REPORT MUST BE SUBMITTED WITHIN 30 DAYS AFTER WELL COMPLETION
FILL IN THIS FORM COMPLETELY
COUNTY NUMBER ANNAPOLIS

DATE RECEIVED (DWR USE ONLY) 11/14/73
DATE WELL COMPLETED 11/14/73
8-13 15 20

DEPTH OF WELL 140
22 (TO NEAREST FOOT) 26

PERMIT NO. FROM "PERMIT TO DRILL WELL" 47-73-0250
28 29 30 31 32 33 34 35 36 37

DRILLER'S IDENTIFICATION NO. 1298

OWNER Joseph Mayne
LAST NAME 18324
STREET OR RFD new mixed rd.

FIRST NAME Walter
POST OFFICE Walter

WELL LOG

STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING

DESCRIPTION (USE ADDITIONAL SHEETS IF NECESSARY)	FEET		CHECK IF WATER BEARING
	FROM	TO	
<u>Sand</u>	<u>0</u>	<u>55</u>	
<u>gray granite</u>	<u>57</u>	<u>140</u>	

WELL DESCRIPTION

GROUTING RECORD

WELL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX) YES NO
TYPE OF GROUTING MATERIAL (CIRCLE BOX) CEMENT BENTONITE CLAY
CEMENT C M BENTONITE CLAY B C
NO. OF BAGS 12 NO. OF POUNDS 1320
GALLONS OF WATER 65
DEPTH OF GROUT SEAL (TO NEAREST FOOT)
FROM 0 FT. TO 50 FT.
48 52 54 56
(ENTER 0 IF FROM SURFACE)

CASING RECORD

CASING TYPES (INSERT APPROPRIATE CODE BELOW)
 S T STEEL C O CONCRETE
 P L PLASTIC O T OTHER
MAIN CASING TYPE S T NOMINAL DIAMETER TOP OF MAIN CASING (NEAREST INCH) 4 TOTAL DEPTH OF MAIN CASING (NEAREST FOOT) 60
60 61 63 64 66 70

OTHER CASING (IF USED)

DIAMETER (INCH) DEPTH (FEET) FROM TO

SCREEN RECORD

SCREEN TYPE OR OPEN HOLE (INSERT APPROPRIATE CODE BELOW)
 S T STEEL B R BRASS OR BRONZE H O OPEN HOLE
 P L PLASTIC O T OTHER

C 2

DEPTH (NEAREST WHOLE FOOT) FROM TO

1	8	9	11	15	17	21
2	23	24	26	30	32	36
3	38	39	41	45	47	51

SLOT SIZE 1. 2. 3.

DIAMETER OF SCREEN 56 (NEAREST INCH) FROM TO

GRAVEL PACK

IF WELL DRILLED WAS A FLOWING WELL CIRCLE BOX F

DWR USE ONLY (NOT TO BE FILLED IN BY DRILLER) (E.P.O.S.)

TELESCOPE CASING LOG INDICATOR OTHER DATA AVAILABLE 74 75 76

C 3

PUMPING TEST

HOURS PUMPED (TO NEAREST HOUR) 2
PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON) 6
METHOD USED TO MEASURE PUMPING RATE direct
WATER LEVEL: (DISTANCE FROM LAND SURFACE) BEFORE PUMPING 60 (NEAREST FOOT) 17 20
WHEN PUMPING 22 (NEAREST FOOT) 25
TYPE OF PUMPED USED (CIRCLE APPROPRIATE BOX) (FOR PUMPING TEST)
 A AIR P PISTON T TURBINE
 C CENTRIFUGAL R ROTARY O OTHER (DESCRIBE BELOW)
 J JET S SUBMERSIBLE

PUMP INSTALLED

TYPE OF PUMP (WRITE APPROPRIATE LETTER IN BOX - SEE ABOVE: A, C, J, P, R, S, T, O)
DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX) YES NO
CAPACITY: GALLONS PER MINUTE (TO NEAREST GALLON) 31 35
PUMP HORSE POWER 37 41
PUMP COLUMN LENGTH (NEAREST FOOT) 43 47

CASING HEIGHT (CIRCLE APPROPRIATE BOX AND ENTER CASING HEIGHT)

ABOVE LAND SURFACE (NEAREST FOOT) 50 51
 BELOW

LOCATION OF WELL ON LOT

SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL).

CIRCLE APPROPRIATE BOXES

- A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED
- E ELECTRIC LOG OBTAINED
- P TEST WELL CONVERTED TO PRODUCTION WELL

I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

DRILLERS NAME Joseph Mayne

(PLEASE PRINT) Joseph Mayne

SIGNATURE Joseph Mayne

Handwritten notes and signatures in the bottom right corner.