

9/15/81 FILE APPROVED
P 31505 C.82

PERMIT

A 25466

9/15/81
as soon as possible

SEWAGE DISPOSAL SYSTEM
MARYLAND STATE DEPARTMENT OF HEALTH*

HOWARD COUNTY

05383773

ELLICOTT CITY

DISTRICT 5th

DATE 7/22/81

INDEX

Paul Schissler

IS PERMITTED TO INSTALL ALTER

ADDRESS 7311 Brangles Road, Marriottsville, Md. PHONE 795-3642

SUBDIVISION 11745 Route 108 ROAD LOT 1

PROPERTY OWNER Jerry Golabowski

ADDRESS 1687 Langford Road, Baltimore, Md. 21207

SPECIFICATIONS 3 bedrooms

SEPTIC TANK CAPACITY 1000 GALLONS

DRAIN FIELD DEPTH FEET, BOTTOM AREA SQ. FT.

DEEP TRENCH DEPTH FEET, BOTTOM AREA SQ. FT.

SEEPAGE PITS ABSORBENT SIDE-WALL AREA 400 ¹²⁰ SQ. FT. per bedroom

INLET PIPE 5 FT. BELOW ORIGINAL GRADE. MAXIMUM DEPTH 13 FT. BELOW ORIGINAL GRADE

EFFECTIVE DEPTH AT FT. BELOW ORIGINAL GRADE.

LOCATE DISPOSAL AREA 212 FT. FROM front LOT LINE AND 72 FT. FROM right side line

FACING LOT FROM Rte 108

NOTE: Okay to use trench off dry well to make upabsorbent sidewall area in system.
Leave 5 ft. earth buffer between trench and dry well. Trench to follow contour of the land. Call for 2 inspections before and after gravel is installed.

PLANS APPROVED BY Raymond Hodges DATE 9/26/77

COVER NO WORK UNTIL INSPECTED AND APPROVED.

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.

NOTE: IF TRENCH IS USED CALL FOR INSPECTION BEFORE PLACING GRAVEL IN TRENCH.

NOTE: NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER.

NOTE: ALL PIPE FROM HOUSE TO DISPOSAL AREA MUST BE CAST IRON.

PERMIT VOID AFTER THREE YEARS.

NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL. STAND PIPES MUST BE 6 INCHES IN DIAMETER. CAST IRON, CONCRETE OR TERRA COTTA ACCEPTED.

*INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT.



CHESAPEAKE
PLUMBING
INC.

*Howard County Health Department
C/O Stuart Oster
7178 Columbia Gateway Drive
Columbia, MD 21046*

To Whom It May Concern:

Chesapeake Plumbing Incorporated abandoned the septic and dry well system for the following properties:

*11745 Route 108 Clarksville- P00133665
11737 Route 108 Clarksville- P00133664*

We performed this job in order to tie in to the county water and sewer lines. If there are any questions regarding this matter, please contact us at the number listed below.

*Sincerely,
Chesapeake Plumbing Inc.*

*Shannon A. O'Connor
Office Administration*