

7/7/82
Before noon

SYSTEM OK

PERMIT

7-7-82
CW - Rth

P 32002

A Repair

SEWAGE DISPOSAL SYSTEM

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

03-291707

ELLICOTT CITY

DISTRICT 4th

DATE 6/29/82

INDEX

Jack Fyock

IS PERMITTED TO INSTALL ALTER X

ADDRESS 13775 Triadelphia Road, Glenelg, Md. 21737

PHONE 988-9270

SUBDIVISION _____ ROAD 3314 Roscommon Drive

LOT _____

PROPERTY OWNER Mr. John Moore

ADDRESS 3314 Roscommon Drive, Glenelg, Md. 21737

SPECIFICATIONS

SEPTIC TANK CAPACITY _____ GALLONS

DRAIN FIELD _____ DEPTH _____ FEET, BOTTOM AREA _____ SQ. FT.

DEEP TRENCH _____ DEPTH _____ FEET, BOTTOM AREA _____ SQ. FT.

SEEPAGE PITS _____ ABSORBENT SIDE-WALL AREA _____ SQ. FT.

INLET PIPE _____ FT. BELOW ORIGINAL GRADE. MAXIMUM DEPTH _____ FT. BELOW ORIGINAL GRADE.

EFFECTIVE DEPTH AT _____ FT. BELOW ORIGINAL GRADE.

LOCATE DISPOSAL AREA _____ FT. FROM _____ LOT LINE AND _____ FT. FROM _____ LOT LINE AS SEEN WHEN FACING LOT FROM

REPAIR - Call for an appointment when ground is opened up and Sanitarian will

recommend the repair system. DIG 2 FT WIDE TRENCH, 11 FT DEEP.

FILL WITH 7 FT GRAVEL; INLET PIPE 4 FT BELOW GRADE. OK TO USE EXISTING DRYWELL

FOR WASHING MACHINE EFFLUENT ONLY, CONNECT TRENCH TO EXISTING SEPTIC TANK IN FRONT YARD,

PLANS APPROVED BY Palmer F. Wine

10 AM 7-7-82 CW & Rth
DATE 6/29/82

COVER NO WORK UNTIL INSPECTED AND APPROVED.

OK TO COVER ALL WORK
3 PM 7-7-82 CW & Rth

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.

NOTE: IF TRENCH IS USED CALL FOR INSPECTION BEFORE PLACING GRAVEL IN TRENCH.

NOTE: NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER.

NOTE: ALL PIPE FROM HOUSE TO DISPOSAL AREA MUST BE CAST IRON.

PERMIT VOID AFTER THREE YEARS.

NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL. STAND PIPES MUST BE 6 INCHES IN DIAMETER. CAST IRON, CONCRETE OR TERRA COTTA ACCEPTED.

*INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT.

P 32002

