

Retist

APPLICATION

SEWAGE DISPOSAL TESTING

STATE OF MARYLAND - DEPARTMENT OF HEALTH AND MENTAL HYGIENE

HOWARD COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SERVICES

P. O. BOX 473 ELLICOTT CITY, MARYLAND 21043
TELEPHONE: 992-2330

A 31813

P _____

DISTRICT 8th

DATE 3/1/82

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TEST IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER George E. & Eugenia M. McCollam

ADDRESS 1019 Hollywood Avenue, Silver Spring, Md. 20904 PHONE _____

PROPERTY LOCATION:

SUBDIVISION Fox Haven LOT NO. 15

ROAD AND DESCRIPTION Route 108

SIZE OF LOT 3.116 acres TYPE BLDG. 3 or 4 bedrooms
(NUMBER OF BEDROOMS)

THE SYSTEM INSTALLED UNDER THIS APPLICATION IS ACCEPTABLE ONLY UNTIL PUBLIC FACILITIES BECOME AVAILABLE. I FULLY UNDERSTAND THE FEE CONNECTED WITH THE FILING OF THIS PERC TEST APPLICATION IS NON-REFUNDABLE UNDER ANY CIRCUMSTANCES. I ALSO AGREE TO COMPLY

WITH ALL M.O.S.H.A. REQUIREMENTS IN TESTING THIS LOT. /s/ Eugenia M. McCollam
(SIGNATURE OF APPLICANT)

APPROVED BY _____ FOR _____ DATE _____

REJECTED BY _____ FOR _____ DATE _____

HOLD PENDING FURTHER TESTS _____ DATE _____

REASONS FOR REJECTION OR HOLDING _____

THIS IS NOT A PERMIT

SOIL PROFILE



□ - original perc
 ① - Extra perc
 35 278

INDICATE NORTH - NAME ADJOINING ROADWAY AS BASE LINE.

6 27 17

DATE	TEST NO.	DEPTH	PRE-WET		TEST - 1" DROP		TIME
			START	STOP	START	STOP	
3/2/82	1D	7 1/2	1015	1027	1027	1048	21
	1S	4	1016	1045	little perc	FAIL	
	1V	15 1/2	TOP	7 FT	CLAY		
			BOT	8 1/2 FT	SANDY		
	1M	5 1/2	1127	1215	little perc	FAIL	
	2V	14 1/2	TOP 7 FT	CLAYISH			
			BOT 7 1/2	SANDY			
	2D	8	136	140	140	151	11
	2S	5	137	230	little perc	FAIL	
	3V	12	TOP	10 FT	CLAY		
			BOT	2 FT	SANDY		
	4S	7 1/2	239	241	241	249	8
	4V	14	TOP	7 FT	CLAY		
			BOT	7 FT	SANDY		

REMARKS _____

TYPE OF SOIL _____

TESTED BY

B. HODGES

ALSO PRESENT

BRUCE PRIES } BACKHOE
 DANNY SEEK }

EHT 10 0