

PERMIT

APPROVED
8/20/81
RH

P 31578

A Repair

SEWAGE DISPOSAL SYSTEM

MARYLAND STATE DEPARTMENT OF HEALTH

8/18/81
8/20/81
HOWARD COUNTY

ELLICOTT CITY

DISTRICT _____

DATE 8/17/81

INDEX

John H. Charney

IS PERMITTED TO INSTALL _____ ALTER X

ADDRESS 3801
38101 Offutt Rd, Randallstown, Md 21133 PHONE 655-0930

SUBDIVISION _____ ROAD 2833 N. Rogers Ave LOT _____

PROPERTY OWNER Nicolaus Novosad

ADDRESS 2833 N. Rogers Ave

SPECIFICATIONS

SEPTIC TANK CAPACITY _____ GALLONS
DRAIN FIELD _____ DEPTH _____ FEET, BOTTOM AREA _____ SQ. FT.
DEEP TRENCH _____ DEPTH _____ FEET, BOTTOM AREA _____ SQ. FT.
SEEPAGE PITS 15x15 ABSORBENT SIDE-WALL AREA 360 SQ. FT.
INLET PIPE 4'± FT. BELOW ORIGINAL GRADE. MAXIMUM DEPTH 10 FT. BELOW ORIGINAL GRADE
EFFECTIVE DEPTH AT 4'± FT. BELOW ORIGINAL GRADE.
LOCATE DISPOSAL AREA _____ FT. FROM _____ LOT LINE AND _____ FT. FROM _____ LOT LINE AS SEEN WHEN
FACING LOT FROM OFF OLD DRY WELL 25'± AS SHOWN ON BACK.

REPAIR-CALL FOR INSPECTION WHEN GROUND IS OPENED UP SO SANITARIAN CAN RECOMMEND REPAIR

8/17/81 UPGRADE SEPTIC TANK WITH APPROVED BAFFLES, REPLACE LINES
WHERE NEEDED; INSTALL NEW DRYWELL OFF OLD DRYWELL; INSTALL
APPROVED CLEAVANTS ON ALL SEWAGE DISPOSAL UNITS.

PLANS APPROVED BY CBD Palmer F. Wine DATE August 17, 1981

- COVER NO WORK UNTIL INSPECTED AND APPROVED.
- NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.
- NOTE: IF TRENCH IS USED CALL FOR INSPECTION BEFORE PLACING GRAVEL IN TRENCH.
- NOTE: NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER.
- NOTE: ALL PIPE FROM HOUSE TO DISPOSAL AREA MUST BE CAST IRON.
- PERMIT VOID AFTER THREE YEARS.
- NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL. STAND PIPES MUST BE 6 INCHES IN DIAMETER. CAST IRON, CONCRETE OR TERRAZZO ACCEPTED.

*INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT.

P. 31578

